



NOTE:
ALL CEILING ARE FIRE RATED
ALL REGISTERS, DIFFUSERS AND GRILLES.

GENERAL NOTES:
1. PROVIDE CEILING RADIATION DAMPER.
2. LOCATE ALL FAN COILS FOR SERVING
FIRE RATED
3. ALL CEILING ACCESS PANES SHOULD BE
FIRE RATED

104-4-1000 KLE
DUCT IN 3" ZERO CLEARANCE
U-LISTED 2000 WALK UP W/RA.
100-000 BISHOPWALKER DAMPST.
UP/DRN.

Revisions	No.	Date
GENERAL REVISIONS	Δ	03/20/06
FINAL PRICING	Δ	10/05/06
HUD FIRM COMMITMENT	Δ	11/22/06

Project:
**THE INN
AT CEDARS**
PORTLAND, MAINE

Drawing Title:
**SECOND FLOOR
DUCTWORK PLAN**

Tsomides Associates
Architects and Planners
389 Elliot Street
Newton Upper Falls, MA 02464
(617) 968-4774, Fax: (617) 968-4783
tma@tsomides.com www.tsomides.com

SEAL
DATE: 02/05/06
SCALE: 1/8" = 1'-0"
DRAWN BY: [Signature]

H-2A

ZADE COMPANY INC.
CONSULTING ENGINEERS
140 BEACH STREET, BOSTON, MA 02111
TEL: (617) 392-4468
FAX: (617) 392-4469
E-MAIL: zco@zadecompany.com