

FIXTURE SCHEDULE

| TYPE | MANUFACTURER | CATALOG NUMBER | VOLT | LAMP | DESCRIPTION |
|------|--------------|-------------------|------|----------------|---|
| A1 | ATLANTIC | 6821E1/2-681DWH | 120 | (2)PL18 | COMPACT FLUORESCENT SPECULAR CLEAR ALZAK PROVIDE DIMMING BALLAST |
| A2 | ATLANTIC | 6821E1/2-681DWH | 120 | (2)PL18 | COMPACT FLUORESCENT SPECULAR CLEAR ALZAK PROVIDE DIMMING BALLAST/BLACK BAFFLE |
| A3 | PROGRESS | P7091-09 | 120 | (1)PL13 | WALL SCONCES IN SKY LIGHT PROVIDE DIMMING BALLAST |
| F1 | LITHONIA | 2PM2-2031TB-36-LD | 120 | (2)J31-TB/SP25 | 2"x2" PARABOLICS PARABOLIC LOUVER |
| F2 | NOT USED | - | 120 | (4)F32-TB/SP35 | 1 1/2"x1 1/2" PARABOLICS |
| FS | LIGHTOLIER | SS45132 | 120 | (1)F32TB | STAGGERED FLUORESCENT FIXTURE |
| ⊗ | EMERGI-LITE | LEDPI/2R | 120 | - | EXIT SIGN |

LAMPS AND BALLASTS SHALL BE IN COMPLIANCE WITH LOCAL UTILITY COMPANY REBATE PROGRAMS. SPECIFICATIONS ABOVE FOR THE FIXTURE TYPE ONLY. FLUORESCENT FIXTURES SHALL HAVE ELECTRONIC BALLASTS THD LESS THAN 1/15

- ### ELECTRICAL SPECIFICATIONS
- 1.1 General
 - A. The General Conditions and Drawings issued for this Project shall be considered complete and ready for operation. Manufacturer's catalogue numbers are shown for reference purposes only. They are meant to provide a general description of the equipment and materials required. Equivalent products by other manufacturers will be considered.
 - 1.2 Scope of Work
 - A. The work under this Specification includes the furnishing of all labor and material, and the installation and testing of all electrical work, including but not limited to a complete and ready for operation. Manufacturer's catalogue numbers are shown for reference purposes only. They are meant to provide a general description of the equipment and materials required. Equivalent products by other manufacturers will be considered.
 - 1.3 Codes and Specifications
 - A. The work shall be conducted in accordance with the latest rules and regulations of the National Electrical Code (NEC), the National Fire Protection Association (NFPA), OSHA codes, National Electrical Codes and NFPA.
 - B. All exposed wiring shall be in electric metallic tubing. All concealed wiring shall be in electric metallic tubing. All wiring shall be in accordance with the latest editions of the National Electrical Code as required, 600V rated.
 - C. All feeder conductors shall be copper. AWG size as noted XHHW insulation, 600V.
 - 1.4 Coordination of Work
 - A. The Contractor shall schedule and coordinate this work with all trades involved to insure proper installation and operation.
 - B. The Contract Drawings are diagrammatic only and indicate the extent, general location and approximate quantity of work. The Contractor shall coordinate all work locations shall be coordinated with Architectural Drawings and Documents of other trades.
 - C. The Contractor shall verify fixture, mounting and location against these elevations and detail drawings. Exact location of all fixtures shall be confirmed with owner's representative prior to rough-in.
 - D. Subcontractors shall submit drawings and product data to the Contractor for review and approval. The Contractor shall submit all drawings and product data to the Architect before transmitting to Architect. Indicate deviations from Contract Documents.
 - E. This Contractor shall give notices, file plans, obtain permits and licenses, pay for all applicable fees, and obtain the necessary approvals from authorities that have jurisdiction.
 - F. Material and equipment shall be UL, ASME and ACA approved for intended service.
 - G. The Contractor shall be responsible for the repair and replacement of any equipment or replace defective materials or installation of no cost to Owner. Correct damage caused in making necessary repairs and replacements under guarantee.
 - H. Submit guarantee to Architect before final payment.

REMOVE THE EXISTING FIXTURES, WIRING, LIGHT FIXTURE ON NIGHT LIGHT CIRCUIT LOOP UP TO LIGHTING PANEL

EXACT LOCATION AND TYPES OF ALL LIGHTING FIXTURES, MOUNTING HEIGHTS AND MOUNTING DETAILS SHALL BE COORDINATED WITH ARCHITECTURAL REFLECTED CEILING PLANS AND ANY CONFLICTS SHALL BE RESOLVED BY THE CONTRACTOR. OBTAIN LATEST COPY OF THE CEILING PLAN FROM ARCHITECT PRIOR TO ANY WORK DONE.

UNLESS NOTED OTHERWISE ALL WIRING SHALL BE IN EMT OR EMT-F. ALL WIRING SHALL BE #12 AWG CU UNLESS NOTED OTHERWISE. ALL WIRING SHALL BE #10 FT SHALL BE #10 CU

NO EXPOSED WIRING IS ALLOWED. ALL CONCEALED WIRING SHALL BE HOSPITAL GRADE. ALL WIRING SHALL BE CONCEALED, RUN IN CONDUIT.

NOTE: RCP SHOWS ALL CEILING WORK EXCEPT THE EXISTING TOILET ROOM 2

SHARED FIXTURE INDICATES NIGHT LIGHT AND EMERGENCY LIGHT CONNECTED TO LOCAL EMERGENCY CIRCUIT

