



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

PERMIT ISSUED

92113140

Portland, Maine, September 17, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. Supersedes application of 12/31/45

The undersigned hereby applies for a permit to erect after repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plus and specifications, if any, submitted herewith and the following specifications:

Location 211 Concord Street Within Fire Limits? no Dist. No. _____
 Owner's name and address Mr & Mrs. R. E. Bailey, 211 Concord St. Telephone 4-3557
 Lessee's name and address _____ Telephone _____
 Contractor's name and address _____ Telephone _____
 Architect Miller & Seal, Inc. Specifications none Plans yes No. of sheets 4
 Proposed use of building Nursing Home and attached garage No. families _____
 Last use Dwelling and attached garage No. families _____
 Material wood No. stories 2 1/2 Heat steam Style of roof pitch Roofing _____
 Other buildings on same lot none
 Estimated cost \$ 1400. Appeal sustained 10/7/46 Fee \$ 1.00

INSPECTION NOT COMPLETED General Description of New Work

To change use of building from dwelling and attached garage to nursing home with attached garage, and to make the following improvements and alterations:

1. Install a standard automatic fire detection and alarm system with detection system covering entire cellar, all public and stair halls, all closets off halls, the kitchen and the first story of the attached garage, and with alarm gongs in suitable locations to surely arouse all occupants of the building in case of fire.
2. To cover garage side of all parts of wall common between garage and house with double thickness of 3/16th inch thick asbestos board, cemented at the joints. To provide in present door opening in this wall from cellar to garage a standard fire-resistant door in metal covered frame, made self-closing by use of liquid door closer, and with threshold of doorway raised no less than six inches above level of garage floor.
3. To completely close the walls at first floor level of both stairs from first floor to cellar by the usual permanent floor joists and flooring of strength equivalent to that of present first floor.
4. Remove dead bolts from locksets on all doors serving as exits from or through patients' rooms.

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____ number of commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? _____
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? _____

APPROVED:

Signature of owner

R. E. Bailey
Mary K. Bailey