

COMMENTS

12/17/00 - Footing all poured. Checked all setbacks. Went over thru requirements w/ contractor.

O.K. to proceed. Recheck at Framing.


1/19/01 went w/ Tom Mackley for Framing, electrical, plumbing. Need a "clearcut" on PVC in crawl space. a. Need hangers on ceiling joists. b. Need to tie ceilings into RARTRAS
OK to clear in for

2/23/01 - Work has been completed & approval to meet the conditions of the permit.

CR27 176 (1-7)

Permit # 00-1364

[Handwritten signature]



Foundation: _____
 Framing: _____
 Plumbing: _____
 Final: _____
 Other: _____

Inspection Record

Type _____
 Date _____