Inspections Division
Date: 11/02/16
Replace existing decking with new 5/4" deck boards
Existing 2"x 6" floor joists attached with joist hangers to 4"x 6" to remain
4"x 4" ledger bolted 2' OC