### Portland, Maine



## Yes. Life's good here.

Jerome F. LaMoria Fire Chief, Fire Department

Portland Fire Department Fire Prevention Bureau 380 Congress St Portland, ME 04101

July 7, 2015

John Lufkin & Sarah J Lufkin 15 Abigail Way Scarborough, ME 04074

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at 282 Stevens Ave on 07/07/2015 revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

Fire Prevention Bureau

# CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

# **Inspection Violations**

| Owner/Manager                             |   |             |                 | Inspector Christopher Goodall Status |      | Inspection Date 7/7/2015       |
|---|---|-------------|-----------------|--------------------------------------|------|--------------------------------|
| LUFKIN JOHN N & SARAH J JTS  Location CBL |   |             | Inspection Type |                                      |      |                                |
| 282 STEVENS AVE                           |   | 176 H004001 |                 | Failed                               |      | Fire Company-FP Routine Inspec |
| Code                                      | ln  | t/Ext       | Floor           | Unit No.                             | Area | Compliance Date                |
| 1) 69.05                                  |   |             |                 |                                      |      |                                |
| Violation:                                | PORTLAND FIRE DEPARTMENT CHAPTER 10 4.3.1, 4.3.2 BUILDING ADDRESS NOT MARKEI ON BUILDING; 4.3.1 Signs shall be located in a position readily visible as approaching from the maccess and approved by the Fire Department. Signs shall be illuminated or retro reflective on a contrasting background and the letter(s) size shall be approved by the Fire Department.         |             |                 |                                      |      |                                |
|   | 4.3.2 Street Address shall be clearly marked on the front of the building and building sign as approved by the Fire Department.   |             |                 |                                      |      |                                |
| Notes:                                    | NUMBER FOR 282 NEEDS REPAIR   |             |                 |                                      |      |                                |
| 2) 80.28                                  |   |             |                 |                                      |      |                                |
| Violation:                                | NFPA 101- 7.5.1.1 EXIT OBSTRUCTED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4. |             |                 |                                      |      |                                |
| Notes:                                    | STORAGE IN HALLWAYS, 3RD FLOOR FRONT AND REAR   |             |                 |                                      |      |                                |
| 3) 81.20                                  |   |             |                 |                                      |      |                                |
| Violation:                                | NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method.   |             |                 |                                      |      |                                |
| Notes:                                    | NO TAG ON EXTINGUISHER IN REAR STAIRWELL GROUND FLOOR   |             |                 |                                      |      |                                |
| 4) 71.25                                  |   |             |                 |                                      |      | -                              |
| Violation:                                | SMOKE ALAR  | MS RE       | QUIRED          |                                      |      |                                |

NO DETECTORS PRESENT IN BASEMENT

Comments:

Notes:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

John Lufkin & Sarah J. Lufkin Defendant

SUMMONS NUMBER:

353817

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on August 10, 2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at <a href="mailto:meservev@portlandmaine.gov">meserve wou of the requirement to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on August 10, 2015.

Dated: 7/9/15

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council

City of Portland 389 Congress St Portland, ME 04101 207-874-8480