Indoor Unit – 1st Fl.
15,000 Btu/hr - Located
living area high up on th
wall

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/18/14

Outdoor Units
Located on the Southwestern gable end of the home and will be mounted on a wall bracket.

Weight of each unit is 88 lbs.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Justin McEdward 199 Stevens Ave., Portland, ME 04103				
	DATE 7/31/2014	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0