

# DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

Please Read  
Application And  
Notes, If Any,  
Attached

BUILDING INSPECTION

PERMIT

Permit Number: 040481

This is to certify that Carpenter Debra & /Curt Pef  
has permission to build 14' x 14' deck w/4' wal  
AT 14 June St

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department:

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and when permission is procured before this building or part thereof is laid or closed-in. HEAR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS  
Fire Dept. \_\_\_\_\_  
Health Dept. \_\_\_\_\_  
Appeal Board \_\_\_\_\_  
Other \_\_\_\_\_  
Department Name

PERMIT ISSUED  
APR 27 2004  
CITY OF PORTLAND

*[Signature]*  
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

5-5-04

Checked Setback & some  
Trees OK 10" 4' depth out  
(NW)

5/20/01 - Checked Treats/users ok - Checked  
Ballusters ok - Framing ok - Rails on Stairs  
need to be 36 inch min (are 33-34.) Owner  
will set it up and call back. Jan M