

Location of Construction: 7 Hale St		Owner: Pochebit, Walter		Phone:		Permit No: 950011	
Owner Address:		Leasee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name: Maine P.O. box 1090 766 Roosevelt Trail, Windham, ME 04062		Address: 766 Roosevelt Trail, Windham, ME 04062		Phone: 892-6744		<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED Permit Issued: JAN 5 1995 </div>	
Past Use: 1-fam		Proposed Use: Same		COST OF WORK: \$ _____ FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		PERMIT FEE: \$ 25.00 INSPECTION: Use Group: Type:	
Proposed Project Description: Install above ground-100 gallon-tank		Signature:		Signature: <i>[Signature]</i>		Zone: CBL: 179-C-003 Zoning Approval:	
Permit Taken By: Mary Gresik		Date Applied For: 4 Jan 95		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *[Signature]* Stephen McCusker ADDRESS: _____ DATE: 4 Jan 95 PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

- Zoning Appeal**
- Variance
 - Miscellaneous
 - Conditional Use
 - Interpretation
 - Approved
 - Denied

- Historic Preservation**
- Not in District or Landmark
 - Does Not Require Review
 - Requires Review

- Action:**
- Approved
 - Approved with Conditions
 - Denied

Date: 1/5/95
[Signature]

CEO DISTRICT 4

[Signature]

BUILDING PERMIT REPORT

DATE: 1/5/95

ADDRESS: 7 Halc St

REASON FOR PERMIT: Install 1-100gal ABOVE GROUND L/P TANKS

BUILDING OWNER: Walter Pacheco, T

CONTRACTOR: Morris

PERMIT APPLICANT Stephen Mc Cushman

APPROVED: DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All above ground L/P storage tanks shall be located in accordance with NFPA #58 standards.
- 2.) Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.
- 3.) All piping shall be protected from possible mechanical damage and vandalism.


Walter Pochebit

7 Hale St.

Portland, Me. 04103

761-2798

1-125



driveway

Hale St.