

Location: Combination Roof And Floor Beam 1  
Combination Roof And Floor Beam  
[2012 International Building Code(AISC 14th Ed ASD)]  
A36 W8x21 x 11.5 FT  
Section Adequate By: 56.7%  
Controlling Factor: Deflection

