Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/23/15

15,000 BTU/hr Indoor Unit
Located in the first floor dining room high up on the exterior wall. Weight of unit is 22 lbs and will be mounted to wall framing.

15,000 BTU/hr Outdoor Unit
Mounted on a ground-mounted stand on concrete pad located on the Southeast facing wall of the home. Weight of unit is 88 lbs.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Brad Nichols 97 Alba Street, Portland, ME				
	DATE 1/26/2015	DRAWN BY Joe Maisonave	PAGE 1 of 1	DWG# 1	Rev. 0