Inspections Division
Date: 08/04/14

HEARTH DOCTOR, INC.
WASHINGTON ST.
AUBURN, ME 04210
(207) 241-2435

COOK JOB

MW DURA-TECH 6" TYPE HT CHIMNEY

TO BE ENCLOSED WITH INSULATED CHASE TO 1' FROM TOP. TEE ACCESS AT BOTTOM FOR CLEANING.