

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

BRALEY GRACE

Located at

11 LEEMAN ST

PERMIT ID: 2014-01175

ISSUE DATE: 06/27/2014

CBL: 181 F001001

has permission to **Change of use to single family with accessory dwelling unit. - install a kitchen, remove a door between units and replace with wall.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Single family with accessory dwelling unit

Building Inspections

Use Group: R-3

Type: 5

Single family home with accessory unit

ENTIRE

MUBEC/IRC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical - Residential

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-01175	Date Applied For: 05/30/2014	CBL: 181 F001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single Family Home w/ accessory dwelling unit		Proposed Project Description: Change of use to single family with accessory dwelling unit. - install a kitchen, remove a door between units and replace with wall.		
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 06/05/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note: R-5 Zone ZBA approved Conditional Use application for the accessory dwelling unit on May 15, 2014.				
Conditions:				
<hr/>				
Dept: Building	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 06/27/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Handrails shall be not less than 34" and not more than 38" in height per IRC R311.7.7.1.				
2) All floors and walls that separate dwelling units or dwelling units and common areas are required to meet a 1 hour fire rated assembly and sound transmission rating of 45 STC.				
3) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all bedrooms, protecting the bedrooms, and on every level.				
The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.				
4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
5) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 06/05/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Carbon Monoxide is detection required in accordance with NFPA 720, Standard for Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition				
2) Photoelectric smoke detectors are required in accordance with NFPA 72				
3) All construction shall comply with City Code Chapter 10.				