


157-156


LOT 68 WAYSIDE ROAD

156 WAYSIDE RD.



more than 10' all around

Patio



RECEIVED
AUG-6 1981
DEPT. OF BLDG. INSP.
CITY OF PORTLAND



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION R-3 PORTLAND, MAINE, ... Aug. 6, 1981

AUG 11 1981

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

CITY of PORTLAND

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 156 Wayside Road 04102
1. Owner's name and address Darrell & Linda DeLong same Fire District #1 [] #2 []
2. Lessee's name and address Telephone 774-9217
3. Contractor's name and address Pool Shed Inc., Box 124 W. Buxton, Me Telephone 727-3439
4. Architect Specifications Plans No. of sheets
Proposed use of building inground swimming pool No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 6,000 Fee \$ 40.00

FIELD INSPECTOR - Mr.

GENERAL DESCRIPTION

This application is for: @ 775-5451 Ext. 234
Dwelling
Garage
Masonry Bldg.
Metal Bldg.
Alterations
Demolitions
Change of Use
Other

To install inground swimming pool 16' x 32' plans on file in office.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 [x] 2 [] 3 [] 4 []

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber - Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE
BUILDING INSPECTION - PLAN EXAMINER
ZONING: D.R. M.E.D. 8/10/81
BUILDING CODE: D.R. M.E.D. 8/10/81
Fire Dept.: Jyle D. Hayes
Health Dept.
Others:

MISCELLANEOUS
Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant Darrell DeLong Phone # same
Type Name of above Darrell DeLong

FIELD INSPECTOR'S COPY


6

Other [] 2 [] 3 [] 4 []
and Address

Permit No. 81/797
Location 156 Nayside Road
Owner Janell De Long
Date of permit 8-6-81
Approved 8-11-81

NOTES

~~10/5/81 - CR - OK~~



R3 RESIDENCE ZONE



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, July 19, 1961

PERMIT ISSUED
00878
JUL 20 1961
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 68 Wayside Road (151-155) Within Fire Limits? _____ Dist. No. _____
Owner's name and address Salvation Army, 616 Congress St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address King Butland, 163 Maine Ave. Telephone _____
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building 1 car garage No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot dwelling
Estimated cost \$ 1200. Fee \$ 6.00

General Description of New Work

To construct 1-car frame garage 14'x24'
9' garage door opening - gable end - ^{4x8}~~4x6~~ header

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO King Butland

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Height average grade to top of plate 8' Height average grade to highest point of roof 12'
Size, front 14' depth 24' No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation concrete slab Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof pitch Rise per foot 5" Roof covering asphalt roofing Class C Und. Lab.
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind hemlock Dressed or full size? dressed
Corner posts 4x4 Sills 2x6 bolted Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-24" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor concrete, 2nd _____, 3rd _____, roof 2x4
On centers: 1st floor _____, 2nd _____, 3rd _____, roof 20"
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 7'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot 0, to be accommodated 1 number commercial cars to be accommodated no
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

APPROVED:

H. E. H.

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Salvation Army

C24 195 50 MAINE PRINTING CO.

INSPECTION COPY

Signature of owner

By:

King Butland


976

Permit No. AT-876
 Location Lot 68 Noyette Rd
 Owner Sabraton Army
 Date of permit 7/21/61
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. _____
 Cert. of Occupancy issued _____

NOTES

7-29-61 location OK
 8-9-61 Completed
 SP
 SP

Multiple vertical lines for notes and signatures, mostly empty.



Way Side Road.
Lot. no. 68
Salvation Army.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for 1 car garage

Date 7/19/61

at Lot 68 Wayside Rd.

1. In whose name is the title of the property now recorded? Salvation Army
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? 6"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

King Butland



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, July 19, 1961

PERMIT ISSUED

00873
JUL 20 1961

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 68 Wayside Rd. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Salvation Army, 616 Congress St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address King Butland, 163 Maine Ave. Telephone _____
Architect _____ Specifications _____ Plans _____ No. of sheets _____
Proposed use of building Dwelling No. families _____
Last use _____ " _____ No. families _____
Material frame No. stories 2 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 400. Fee \$ 3.00

General Description of New Work

To construct roof over existing 4'x8' side platform and to glass-in.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Kind of roof pitch Rise per foot 5" Roof covering asphalt roofing Class C Und. Lab.
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber-Kind hemlock Dressed or full size? dressed Corner posts 4x4 Sills _____
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof 2x4
On centers: 1st floor _____, 2nd _____, 3rd _____, roof 20"
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 4'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

J. E. M.

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Salvation Army

CS 301

INSPECTION COPY

Signature of owner By:

King Butland

PH



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, April 25, 1961

PERMIT ISSUED 00382 APR 28 1961 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 68 Wayside Road Use of Building Dwelling No. Stories 2 New Building Existing
Name and address of owner of appliance The Minat. Corp., 34 Preble St.
Installer's name and address Pallotta Oil Company 112 Exchange St. Telephone

General Description of Work

To install Forced hot water heating system and oil burning equipment.

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace: 3'
From top of smoke pipe 18" From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 8x8 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Delco-guntype Labeled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] OK 4-25-61

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Pallotta Oil Company

Signature of Installer by: [Signature]

INSPECTION COPY

CS 300

F M

Permit No. 61/383
 Location Lot 68 Myrtle Road
 Owner The Trust Corp.
 Date of permit 4/26/61
 Approved _____

1	Site map	
2	Weathering	
3	Kind of fluid	
4	Surrounding structures	
5	Stack height	
6	Stack location	
7	High stack location	
8	Barometric pressure	
9	Piping size and material	
10	Valves to shut off	
11	Capacity of tanks	
12	Tank height and diameter	
13	Tank diameter	
14	Oil gauge	
15	Insulation	
16	Low level alarm	

NOTES

8-4-61 Completed

X



APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. #1

Portland, Maine, March 24, 1961

PERMIT ISSUED

MAR 29 1961

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 60/1159 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Lot 28 Wayside Rd. Within Fire Limits? Dist. No. _____

Owner's name and address The Minat Corp., 34 Preble St. Telephone _____

Lessee's name and address _____ Telephone _____

Contractor's name and address Owners Telephone _____

Architect _____ Plans filed yes. No. of sheets _____

Proposed use of building Dwelling No. families 1

Last use _____ No. families _____

Increased cost of work _____ Additional fee .50

Description of Proposed Work

To construct inside stairway from second floor to attic space
 To change pitch of roof to 8" in 12.
 To replace 8x8 Douglas Fir girder with 6B12 steel beam as per plan

Approved with Lot 67

Permit Issued with Letter

Details of New Work owner

Is any plumbing involved in this work? Is any electrical work involved in this work? _____

Height average grade to top of plate _____ Height average grade to highest point of roof _____

Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Framing lumber—Kind _____ Dressed or full size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor _____ 2nd _____ 3rd _____ roof _____

On centers: 1st floor _____ 2nd _____ 3rd _____ roof _____

Maximum span: 1st floor _____ 2nd _____ 3rd _____ roof _____

Approved: _____

Signature of Owner By: *Albert Sears*
 Approved: _____
 Inspector of Buildings

BP- 60/1159- Lot ⁶⁷ 68 Wayside Road

March 29, 1961

The Minat Corporation
34 Preble Street

Gentlemen:

Permit amendment involving use of steel instead of wood girder in dwelling under construction at the above named location, and for changing pitch of roof and providing attic floor and stairway leading thereto, is issued herewith based on plan filed with application for amendment, but subject to the following conditions:

1. Where pitch of roof is to be increased so as to provide an attic floor with stairway leading thereto, attic floor joists are to be fastened to rafters with no less than five 20 penny nails at each location.
2. Inasmuch as attic floor timbers are spaced 20 inches on centers and rough flooring has already been laid on them, it will be necessary to lay plywood not less than $\frac{3}{8}$ of an inch in thickness on top of the rough flooring. In the case of buildings not already constructed where similar framing is to be provided, rafters and attic floor timbers will need to be spaced not over 18 inches on centers if an attic floor of ordinary boarding is to be provided. If the 20 inch spacing is to be maintained, the use of $\frac{5}{8}$ inch thick plywood would satisfy Building Code requirements.

Very truly yours,

Albert J. Sears
Director of Building Inspection

AJS:m

PERMIT NUMBER **9879**

Date Issued **3/21/61**

PORTLAND PLUMB'NG INSPECTOR

By **J. P. Welch**

APPROVED FIRST INSPECTION

Date **Aug 31 1961**

By **JOSEPH P. WELCH**

APPROVED FINAL INSPECTION

Date **Aug 31 1961**

By **JOSEPH P. WELCH**

- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

PERMIT TO INSTALL PLUMBING

Address: **Lot 68 Wayside**

Installation For: **Wheat Corporation**

Owner of Bldg.: **Wheat Corporation**

Owner's Address: **36 Probio Street**

Plumber: **William E. Miles Sr.** Date: **3/21/61**

NEW	REP'L	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS	1	\$ 2.00
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS	3	
		GARBAGE GRINDERS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS (conn. to house drain)		
			1	\$ 2.00
			Total	\$ 2.00

SA 12-53 PORTLAND HEALTH DEPT. PLUMBING INSPECTION **Total**

SA 12-53 PORTLAND HEALTH DEPT. PLUMBING INSPECTION **Total** **\$13.00**

REMODELING

SA 12-53 PORTLAND HEALTH DEPT. PLUMBING INSPECTION **Total** **\$ 2.00**

PERMIT NUMBER **330**

Date **10-3-60**

PORTLAND PLUMBING INSPECTOR

J. P. Welch

APPROVED FIRST INSPECTION

Date **Mar. 20-61**

By **JOSEPH P. WELCH**

APPROVED FINAL INSPECTION

Date **Aug. 31-1961**

By **JOSEPH P. WELCH**

TYPE OF BUILDING

- COMMERCIAL
- RESIDENTIAL
- SINGLE
- MULTI FAMILY
- NEW CONSTRUCTION
- REMODELING

SM 12-53 PORTLAND HEALTH DEPT.

REMODELING

SM 12-53 PORTLAND HEALTH DEPT.

PERMIT TO INSTALL PLUMBING **W.K.**

Address: **Lot 68 Wayside Road**

Installation For: **Minat Corporation**

Owner of Bldg.: **Minat Corporation**

Owner's Address: **34 Preble Street**

Plumber: **William E. Miles Sr.**

Date: **10-3-60**

NEW	REP'L	PROPOSED INSTALLATIONS	NUMBER	FEE
1		SINKS	1	\$ 2.00
2		LAVATORIES	2	4.00
2		TOILETS	2	4.00
1		BATH TUBS	1	.60
1		SHOWERS	1	.60
1		DRAINS	1	.60
1		HOT WATER TANKS	1	.60
1		TANKLESS WATER HEATERS	1	.60
1		GARBAGE GRINDERS	1	.60
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS (conn. to house drain)		
1		Washing Machine	1	.60
			10	11.00
			Total	
			1	2.00
			Total	

PERMIT NUMBER 8780

5-9-60
PORTLAND PLUMBING INSPECTOR

By J.P. Welch
APPROVED FIRST INSPECTION

Date May 27-60
By JOSEPH P. WELCH

APPROVED FINAL INSPECTION
Date June 13, 60
By JOSEPH P. WELCH

- TYPE OF BUILDING
- COMMERCIAL
- RESIDENTIAL
- SINGLE
- MULTI FAMILY
- NEW CONSTRUCTION
- REMODELING

SM 12-53

PORTLAND HEALTH DEPT.

PERMIT TO INSTALL PLUMBING

Address: Lot 68 Wayside Road V
 Installation For: Minut Coys.
 Owner of Bldg.: Minut Coys.
 Owner's Address: 34 Peckham Street
 Plumber: William E. Mink
 Date: 5-9-60

NEW	REP	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
		GARBAGE GRINDERS	3	
		SEPTIC TANKS		
1		HOUSE SEWERS		
		ROOF LEADERS (conn. to house drain)	1	22.00
			Total	22.00

PLUMBING INSPECTION



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure August 16, 1960
Portland, Maine, Third Class

PERMIT ISSUED
AUG 18 1960
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 22 Sideside Road Within Fire Limits? Dist. No.
 Owner's name and address The Minat. Corp. 3/4 Freble St. Telephone
 Lessee's name and address owners Telephone
 Contractor's name and address Telephone 4-8013
 Architect Specifications Plans yes No. of sheets 3
 Proposed use of building Dwelling No. families 1
 Last use No. families
 Material frame No. stories 2 Heat Style of roof Roofing
 Other building on same lot
 Estimated cost \$ 14,000 Fee \$ 14.00

General Description of New Work

To construct 2-story frame dwelling house 32' x 24'

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owners

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
 Is connection to be made to public sewer? yes If not, what is proposed for sewage?
 Has septic tank notice been sent? Form notice sent? yes
 Height average grade to top of plate 16' Height average grade to highest point of roof 26'
 Size, front 32' depth 24' No. stories 2 solid or filled land? solid earth or rock? earth
 Material of foundation concrete at least 4' below grade Thickness, top 9" bottom 12" cellar yes
 Material of underpinning " to sill Height Thickness
 Kind of roof pitch Rise per foot 6" Roof covering Asphalt Class C Und. Lab.
 No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat f.h. water oil
 Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts 4x6 Sills box
 Size Girder 8x9 f.s. Columns under girders Lally Size 2 1/2" Max. on centers 7'7"
 Kind and thickness of outside sheathing of exterior walls?
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x8 ceiling 2x8 roof 2x8
 On centers: 1st floor 16" 2nd 16" 3rd 20" roof 20"
 Maximum span: 1st floor 12' 2nd 12' 3rd
 If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

O.W. 8/18/60 - [Signature]

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
The Minat. Corp.

[Signature]

INSPECTION COPY Signature of owner by:

FM

lot 68

Permit No: 60/1159
 Location Lot 68 Wayside Road
 Owner The Minch Corp.
 Date of permit 8/18/60
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. 8/3/61
 Final Inspn. 8-4-61 AP
 Cert. of Occupancy issued 8/14/61 AP
 Staking Out Notice _____
 Form Check Notice Forms OK

Amend #1 not used

NOTES

5-7-61 OK to Close in AP
 8-4-61 Final all
OK AP

J

(COPY)

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION Lot 68 Wayside Road

Issued to The Minat Corp.
31 Franklin St.

Date of Issue August 11, 1961

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 60/1159, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

One family dwelling house.

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

Nelson F. Cartwright

Albert J. Sears

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

May 3 1960


Boundary Markings and Street grades are based on Survey by Carl & Mary E. E. Survey plates are available
SCALE 1" = 50 ft.

PROPOSED DWELLING LONGFELLOW WOODS

LOT 53 WOODFIELD RD
54 WAYSIDE RD
55
69
70


WOODFIELD RD

PROPOSED ST.



WAYSIDE

ROAD



16" Projection on all 2nd floor front elevations


rankings and
are based on
City of Portland
available
50 ft.

PROPOSED DWELLINGS AT LONGFELLOW WOODS

LOT 53 WOODFIELD RD.
54 WAYSIDE RD.
55
69
70

Owner
Contractor
Plan Maker


THE MINAT
CORP.




RECEIVED
AUG 16 1960
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

7.68 Maypole Rd
14,000

See # 55 Maypole Rd




SECOND FLOOR PLAN




REAR ELEVATION



SIDE ELEVATION




LEFT END ELEVATION



FRONT ELEVATION


THE MINAT CORP.




LEFT END ELEVATION

SECTION


THE MINAT CORP., PORTLAND, MAINE



BASEMENT PLAN



FIRST FLOOR PLAN
SCALE 1/4" = 1'-0"



FIRST FLOOR PLAN
 SCALE 1/4" = 1'-0"

901860

Permit # 901860 City of Portland BUILDING PERMIT APPLICATION Fee 500. Zone Map # Lot#
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Salvation Army Phone # 774-5304
 Address: 297 Cumberland Ave; Ptd, ME 04101
 LOCATION OF CONSTRUCTION 155 Wayside Rd.
 Contractor: Talar Corp. Sup. 439-5919 - 27 Jun 90
 Address: 11 Russell Rd; Eliot, ME 03903 Phone # 437-2511
 Est. Construction Cost: 15,000. Proposed Use: 1-fam w addition
 Past Use: 1-fam
 # of Existing Res. Units # of New Res. Units
 Building Dimensions L W Total Sq. Ft.
 # Stories: # Bedrooms Lot Size:
 Is Proposed Use: Seasonal Condominium Conversion
 Explain Conversion Construct addition- 12'x15'

For Official Use Only PERMIT ISSUED
 Date 9/4/90 Subdivision:
 Inside Fire Limits Name SEP 6 1990
 Bldg Code Lot
 Time Limit Ownership: City of Portland
 Estimated Cost 15,000.
 Zoning: R-3
 Street Frontage Provided:
 Provided Setbacks: Front Back Side Side
 Review Required:
 Zoning Board Approval: Yes No Date:
 Planning Board Approval: Yes No Date:
 Conditional Use: Variance Site Plan Subdivision
 Shoreland Zoning Yes No Floodplain Yes No
 Special Exception
 Other (Explain) on WRD - 9-6-90

Foundation:
 1. Type of Soil:
 2. Set Backs - Front Rear Side(s)
 3. Footings Size:
 4. Foundation Size: 8" poured concrete
 5. Other

Floor:
 1. Sills Size: 2x6 PT Sills must be anchored.
 2. Girder Size:
 3. Lally Column Spacing: 2x4 Size:
 4. Joists Size: 2x8 Spacing 16" O.C.
 5. Bridging Type: Size:
 6. Floor Sheathing Type: Size:
 7. Other Material:

Exterior Walls:
 1. Studding Size 2x4 Spacing 16 O.C.
 2. No. windows 2
 3. No. Doors 1 6x4x8 SLIDER
 4. Header Sizes 2x8 Span(s) 3', 6'
 5. Bracing: Yes No
 6. Corner Posts Size
 7. Insulation Type R-10 GLAS Size
 8. Sheathing Type 5/8 CDX Size
 9. Siding Type AL Weather Exposure
 10. Masonry Materials
 11. Metal Materials

Interior Walls:
 1. Studding Size Spacing
 2. Header Sizes Span(s)
 3. Wall Covering Type 1/2 ROCK
 4. Fire Wall if required
 5. Other Materials

Ceiling:
 1. Ceiling Joists Size: 2x8
 2. Ceiling Strapping Size 1x3 Spacing 16 5/8 HISTORIC PRESERVATION
 3. Type Ceilings: ROCK Does not require rafters.
 4. Insulation Type R-30 GYS Size Requires Review.
 5. Ceiling Height: 96"

Roof:
 1. Truss or Rafter Size 2x8 Span Action: Approved.
 2. Sheathing Type 5/8 CDX Size Approved with Code.
 3. Roof Covering Type Asphalt

Chimneys:
 Type: Number of Fire Places

Heating:
 Type of Heat: 1-FHW

Electrical:
 Service Entrance Size: Smoke Detector Required Yes No

Plumbing:
 1. Approval of soil test if required Yes No
 2. No. of Tubs or Showers
 3. No. of Flushes
 4. No. of Lavatories
 5. No. of Other Fixtures

Swimming Pools:
 1. Type:
 2. Pool Size: x Square Footage
 3. Must conform to National Electrical Code and State Law.

Permit Received By Louise E. Chase
 Signature of Applicant Date
 Signature of CEO Tap Taylor Date 09/04/90

Inspection Dates
 White-Tax Assessor Yellow-GPCOG White Tag -CEO 2 Copyright GPCOG 1988

PLOT PLAN

9/17 foundation/retrofits OK
10/15 Framing/die OK OK to close
2/19 - Completed OK



FEES (Breakdown From Front)		Inspection Record	
Base Fee \$	Type	Date	
Subdivision Fee \$ <u>95-</u>		/	/
Site Plan Review Fee \$ _____		/	/
Other Fees \$ _____		/	/
(Explain) _____		/	/
Late Fee \$ _____		/	/

COMMENTS

Signature of Applicant _____ Date _____

RECEIVED

SEP 04 1990

DEPT OF BUILDING INSPECTIONS
CITY OF PORTLAND

PLC. PLAN SHOWING BUILDINGS



ON LOT #68
Sec. B

LONGFELLOW WOODS

PORTLAND, MAINE

January 1961

Not to Scale



I hereby certify that the buildings
on this lot is within all lot lines
and conforms with the restrictions
of record.

Carl E. Egan
Registered Civil Engineer

NOTE: DISTANCES FROM HOUSE TO
LOT LINES ARE AS SHOWN ON PLAN

THOMAS CORP
439-6945
TAPPAHAN
1/4

RECEIVED

SEP 04 1990

DEPT OF ENGINEERING
CITY OF PORTLAND

PLC. PLAN SHOWING BUILDINGS



ON LOT #68
Sec. B

LONGFELLOW WOODS

PORTLAND, MAINE

January 1961

Not to Scale



100.00
76.5
330
100.00

155 WAYSIDE ROAD


I hereby certify that the buildings on this lot is within all lot lines and conforms with the restrictions of record.

Frank E. [Signature]
Registered Civil Engineer

NOTE: DIMENSIONS FROM HOUSE TO [unclear]

TAPPALE CORP
439-6949
TAP TAP [unclear] 2/4

EXISTING DWELLING



RECEIVED

SEP 04 1990

DEPT. OF BUILDING AND CITY OF PORTLAND

155 WAYSIDE RD
PORTLAND
LOT 68 SEC. B

ROOM ADDITION
SALVATION ARMY
RESIDENCE

TAMAR CORP
439-6549
TAP TAYLOR


3/4

RECEIVED

SEP 04 1990

DEPT. OF BUIL.
CITY OF

EXISTING
HOUSE



24310 LOC-760

155 WAYSIDE RD.
PORTLAND LOT 69 SEC. 12

ROOM ADDITION
SALVATION ARMY
RESIDENCE

TAMAR COMP
439-6945
4/4 TAP TAYLOR



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date 1/2/91, 19____
 Receipt and Permit number 01825

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 155 Wayside Dr
 OWNER'S NAME: Salvation Army ADDRESS: _____

	FEES
OUTLETS: Receptacles <input checked="" type="checkbox"/> Switches _____ Plugmold _____ ft. TOTAL <u>20</u>	2.00
FIXTURES: (number of) Incandescent _____ Fluorescent _____ (not strip) TOTAL _____ Strip Fluorescent _____ ft.	
SERVICES: Overhead <input checked="" type="checkbox"/> Underground _____ Temporary _____ TOTAL amperes <u>200</u> ..	15.00
METERS: (number of) _____	
MOTORS: (number of) Fractional _____ 1 HP or over _____	
RESIDENTIAL HEATING: Oil or Gas (number of units) _____ Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____ Oil or Gas (by separate units) _____ Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of) Ranges _____ Water Heaters _____ Cook Tops _____ Disposals _____ Wall Ovens _____ Dishwashers _____ Dryers _____ Compactors _____ Fans _____ Others (denote) _____ TOTAL _____	
MISCELLANEOUS: (number of) Branch Panels _____ Transformers _____ Air Conditioners Central Unit _____ Separate Units (windows) _____ Signs 20 sq. ft. and under _____ Over 20 sq. ft. _____ Swimming Pools Above Ground _____ In Ground _____ Fire/Burglar Alarms Residential _____ Commercial _____ Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ over 30 amps _____ Circus, Fairs, etc. _____ Alterations to wires _____ Repairs after fire _____ Emergency Lights, battery _____ Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	DOUBLE FEE DUE:
	TOTAL AMOUNT DUE: <u>17.00</u>

INSPECTION:
 Will be ready on _____, 19____; or Will Call
 CONTRACTOR'S NAME: James Plamondon
 ADDRESS: Box 1161 - Biddeford
 TEL: 282-4248
 MASTER LICENSE NO.: #04888 SIGNATURE OF CONTRACTOR: _____
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date 10/10/90, 1990
 Receipt and Permit number 01648

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 155 Wayside Ave.
 OWNER'S NAME: Salvation Army ADDRESS: _____
 (Peter Stritzinger)

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL <u>8</u>	3.00
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL <u>1-10</u>	3.00
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____ ..	
MEIERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	DOUBLE FEE DUE:
	TOTAL AMOUNT DUE: <u>6.00</u>

INSPECTION: Will be ready on _____, 1990; or Will Call x
 CONTRACTOR'S NAME: James Plamondon Electric
 ADDRESS: Biddeford, ME
 TEL: 282-4248
 MASTER LICENSE NO: 04888
 LIMITED LICENSE NO: _____

SIGNATURE OF CONTRACTOR:

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 01648

Location 155 W. 1st St. AUB

Owner Salvatore's Academy

Date of Permit 10-10-90

Final Inspection 6-6-91

By Inspector [Signature]

Permit Application Register Page No. 47

INSPECTIONS: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: 12/15/90, FC, _____

_____, _____

_____, _____

_____, _____

_____, _____

_____, _____

DATE:

10/15/90

REMARKS:

ROUGH IN FOR SMALL 12x12 ROOM (RECEPTALS)
METAL PLATE ON BOTTOM OF ONE CIRCUIT.

NOTE → OF WIRE LAYING ON GROUND NEAR RUBBISH PANS
W/SPICE TO 3 SINGLE UNDERGROUND CONDUCTORS -
(WATER PUMP TYPE)
TOLD TO REPLACE COMPLETE LINE AND BURY IN THE GROUND.