New Floor Plan
14 Wayside

Drm@Portlandmaine.Gov 874-8705



Verify frost protection and span and girder size and support per Table 502.5(2) and R403.1

Provide complete framing details for enclosed porch rasided floor, per Table 502.3.1(1) & Table 502.3.1(2)

Is window going to be within 60 inches of new shower

Please provide all sepecifications on LVLs at each location where installed.

Please add the changes of wall openings and wall sizes

16 Wayside - Existing -