



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions

### Outdoor Unit

Located on northern gable end of h  
supported by a bracket attached to  
members.

Weight of unit is 88 lbs. Minimum o: Date: 05/28/14  
steel lag bolts to attach bracket.



### Indoor Unit

Located in the first floor of the home in the dining area  
on the exterior wall.

Weight of unit is 22 lbs. Unit to be mounted to wall  
framing with 2.5" fasteners sufficient to support the  
unit.

### Notes:

Home is built of traditional wood framing and is  
sufficient to support the additional load of the  
equipment being installed.

ReVision Energy	HVAC Equipment Layout				
	Winter Residence 50 Alden Circle, Portland, ME				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	DATE 4/16/2014	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0