




FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the **INSPECTOR OF BUILDINGS, PORTLAND, ME.**

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 76 Alden Circle / 82AA19 Use of Building residence Date 10-27-05

Name and address of owner of appliance John Sullivan

Installer's name and address Dead River Co. 73 Pleasant Hill Rd Scarborough ME 04074
Telephone 883-9515

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Peerless ECT. Boiler

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF **NO** Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # MS30008108
- Gas # _____
- other _____

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 275 replacing _____

Number of Tanks 1

Distance from Tank to Center of Flame 5' min feet,

Cost of Work: \$ 7,600.00

Permit Fee: \$ 93.00

Approved

Approved with Conditions

Fire: _____

Ele.: _____

Bldg.: _____

See attached letter or requirement

Inspector's Signature

Date Approved

Signature of Installer

Dead River Co. by Jaime Lavigne

White - Inspection


Yellow - File

Pink - Applicant's

Gold - Assessor's Copy




Limited Partnership




UL 80 Domestic Oil Tanks

#PRODUIT	MODELS	DIMENSIONS			GAUGE	WEIGHT
		H	W	L		
2090	120 us gals vertical	47"	23"	30"	12 ga	165 lb
2095	120 us gals horizontal	23"	47"	30"	12 ga	165 lb
2080	138 us gals vertical	44"	27"	30"	12 ga	175 lb
2085	138 us gals horizontal	27"	44"	30"	12 ga	175 lb
2070	220 us gals vert./stubbies	44"	27"	48"	12 ga	240 lb
2075	220 us gals horizontal	27"	44"	48"	12 ga	240 lb
2020	240 us gals narrow/vert.	47"	23"	60"	12 ga	260 lb
2025	240 us gals narrow/horiz.	23"	47"	60"	12 ga	260 lb
2040	275 us gals vertical	44"	27"	60"	12 ga	280 lb
2045	275 us gals horizontal	27"	44"	60"	12 ga	280 lb
2050	330 us gals vertical	44"	27"	72"	12 ga	320 lb
2055	330 us gals horizontal	27"	44"	72"	12 ga	320 lb



TECHNICAL SPECIFICATIONS

- o Steel ASIMA-569
- o Female openings NPT
- o Tested at pressure 5 to 7 PSIG
- o UL 80 label
- o Operation at atmospheric pressure only
- o Also available UL 142 labeled on 275 & 330 gals (including a 3" diameter emergency vent opening). Other models on request only.



Installation and maintenance guidelines for aboveground-domestic-fuel oil tanks.. (PDF;

OUTSIDE FINISH

- o Preparation: **Washed and phosphated**
- Electrostatic powder paint "black or gray".

GENERAL CHARACTERISTICS

- o **Always a tough tank**
- o Welded lap joint: the strongest one
- o Ergonomic handle on each head for easy handling

NEW PRODUCTS:

- 275 gals. UL 80 labelled **10** gauge shell 8

IN REFERENCE TO: UL LISTING

UL Listing: Requires outlet opening of 1/2" minir to be located underneath the tank only. Requires openings to be 2" minimum diameter. Tanks whic not meet **above** requirements cannot be UL 80 la

NOTICE: N.F.P.A. Codes. UL and Granby Steel Tanks require t these tanks be tested at job site before being put in service. To te tank, apply internal air pressure of not less than 3 PSIG or more t PSIG and soap all seams and welded areas. Warning: Over pressurization may cause tank to fail.

