### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

HAWKINS LISE S & SONYA S HAWKINS JTS

Located at

15 JEANNE CT

**PERMIT ID:** 2014-01872

**ISSUE DATE:** 09/22/2014

**CBL:** 183 B045001

has permission to **Build a two story, attached, two car garage (26' x 27.5') with living space above.** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

**Building Official** 

Type: 5B

## THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

Single Family Home

Use Group: R-3

**ENTIRE** 

MUBEC/IRC 2009

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Setbacks and Footings Prior to Pouring Foundation/Backfill Close-in Plumbing/Framing Electrical Close-in Final - Electric Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

### City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

**Permit No:** 2014-01872

Date Applied For: 08/20/2014

CBL:

183 B045001

Proposed Use:

Single-Family Home

**Proposed Project Description:** 

Build a two story, attached, two car garage (26' x 27.5') with living space above.

**Dept:** Zoning **Status:** Approved w/Conditions **Reviewer:** Ann Machado **Approval Date:** 09/02/2014

Note: R-3 Zone Ok to Issue: ✓

lot size = 10,121 sf

front 25' min. - 37' given - OK Rear - 25' min. - 30' given - OK

Side - 2 stories - 14' min. - 11.5' given on right & 18' given on left - \* can reduce right 2.5' if add on to left -

14' + 2.5' = 16.5 min.on left - OK

Lot coverage = 3542.35 sf - 1140 sf existing + 715 = 1855 sf - OK

#### **Conditions:**

- 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.
- 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

**Dept:** Building **Status:** Approved w/Conditions **Reviewer:** Laurie Leader **Approval Date:** 09/19/2014 **Note:** Ok to Issue: ✓

#### **Conditions:**

1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all bedrooms, protecting the bedrooms, and on every level.

The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.

- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.
- 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Craig Messinger
 Approval Date:
 09/18/2014

 Note:
 Ok to Issue:
 ✓

#### **Conditions:**

- 1) Single-station Carbon Monoxide (CO) alarms powered by the building's electrical service with battery backup are required within the dwelling units. CO alarms shall be installed in the following locations:
  - (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms
  - (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces New CO alarms shall be hardwired.
- 2) Hardwired single-station smoke alarms are required within the dwelling units. Smoke alarms shall be installed in the following locations:
  - (1) All sleeping rooms
  - (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms
  - (3) On each level of the dwelling unit, including basements.

New smoke alarms shall be photoelectric powered by the building's electrical service with battery backup.

- 3) Shall be protected by Sprinkler system in accordance to NFPA 13D.
- 4) All construction shall comply with City Code Chapter 10.

**PERMIT ID:** 2014-01872 **Located at:** 15 JEANNE CT **CBL:** 183 B045001