GENERAL NOTES

- 1. All dimensions and conditions must be verified in the field. Any All dimensions and conditions must be verified in the field. Any discrepancies shall be brought to the attention of the engineer before proceeding with the affected part of the work.
 Do not scale plans.
 Sections and details shown on any structural drawings shall be considered typical for similar conditions.
 All proprietary products shall be installed in accordance with the manufacturers written instructions.

- All proprietary products shall be installed in accordance with the manufacturers written instructions.
 The structure is designed to be self supporting and stable after the Framing is complete. It is the contractor's sole responsibility to determine erection procedures and sequencing to ensure the safety of the building and its components during erection. This includes the addition of necessary shoring, sheeting temporary bracing, guys or tile downs. Such material shall remain the property of the contractor after completion of the project.
 All applicable federal, state, and municipal regulations shall be followed, including the federal department of labor occupational safety and health act.

DESIGN LOADS:

- 1. Building code: International Building Codes (IBC and IRC 2009)
- 2. Design Live Loads:30 psf Bedrooms (Level 2), 40 psf Living Space (Level 1), 20 psf Attic Space.
- 3. Design Wind loads: N/A
- 4. Design Seismic loads: N/A

FOUNDATION NOTES:

- 1. Foundations have been designed to conform with the presumptive bearing pressures provided in the International Building Code to be verified by the Owner prior to construction.
- 2. Settlement of the soil below the footings is beyond the scope of this contract and remains the responsibility of the owner at their request.
- 3. Structural fill shall be used at all locations below footings and slabs and adjacent to the foundation walls. Prior to placement of structural fill, remove all topsoil and other unsuitable material. Compacted structural fill shall consist of clean granular material free of organics, loam, trash, snow, ice, frozen soil or any other objectionable material. It shall be well graded within the following units

SCREEN OR SIEVE SIZE PERCENT FINER BY WEIGHT 100 4 inch 3 inch 90 to 100 25 to 90

1/4 inch NO. 40 0 to 30 NO. 200 0 to 5

CONCRETE NOTES:

- 1. All concrete work shall conform to ACI 318-Latest Edition.
- 3. All concrete shall be air entrained 4% to 6%
- 4. Concrete shall not be placed in water or on frozen ground.
- 5. Reinforcing bars shall conform to ASTM A615 Grade 60 deformed
- bars, and shall be detailed, fabricated and erected in accordance with ACI 315-Latest edition.

TIMBER FRAMING:

- 1. All timber framing shall be in accordance with the AITC timber construction manual or the national design specifications (NDS) -latest edition.
- 2. Individual timber framing members shall be visually graded, minimum grade #2 Spruce-Pine-Fir (SPF), kiln dried to 19% maximum moisture
- ground, concrete or masonry. Timber shall be southern yellow pine

- 5. Provide Simpson H3 hurricane anchors where timber framing and/or



THESE DRAWINGS HAVE BEEN DEVELOPED BY MFL ENGINEERING FOR THE TITLED SET ONLY. THE DRAWINGS ARE THE SOLE PROPERTY OF MFL ENGINEERING AND THEY SHALL NOT BE USED, LENT, COPIED OR ALTERED WITHOUT THE WRITTEN CONSENT OF MFL ENGINEERING.