

**... Fire Protection by Computer Design**

High Tech Fire Protection  
84 Hackett Mills Road Poland  
P.O. Box 154 Minot, ME  
Poland, ME 04274  
207-998-2551

Job Name : 1ST FLOOR SHALOM HOUSE  
Building : Shalom House  
Location : 503 Woodford Street Portland  
System : zone 1  
Contract :  
Data File : 1st floor.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Shalom House 1st Floor pendent Date - 9/13/13  
Location - 503 Woodford Street Portland  
Building - Shalom House System No. - zone 1  
Contractor - High Tech Fire Protection Contract No. -  
Calculated By - Ed Poulin Drawing No. - FP-01  
Construction: (x) Combustible ( ) Non-Combustible Ceiling Height 8'  
OCCUPANCY - Residential 13R

S Type of Calculation: ( )NFPA 13 Residential (x)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 (x)4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 14 Gpm System Type  
Listed Pres. at Start Point - 8.2 Psi (x) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 16 x 16 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - na Gpm Sprinkler or Nozzle  
S Additional Flow Added - na Gpm Make GLOBE Model GL4910  
I Elevation at Highest Outlet - 17 Feet Size 1/2" K-Factor 4.9  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 61 Psi Required 49 At Test  
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 9-14-13 Rated Cap. Cap.  
T Time of Test - 8:30 am @ Psi Elev.  
E Static (Psi) - 84 Elev.  
R Residual (Psi) - 82 Other Well  
Flow (Gpm) - 1186 Proof Flow Gpm  
S Elevation - 5

P Location: Test Hydrant # 01978 on Woodford Street

P  
L Source of Information: Portland Water District  
Y


# Water Supply Curve (C)

High Tech Fire Protection  
1ST FLOOR SHALOM HOUSE

Page 2  
Date 9/13/13

City Water Supply:  
C1 - Static Pressure : 84  
C2 - Residual Pressure: 82  
C2 - Residual Flow : 1186

Demand:  
D1 - Elevation : 5.197  
D2 - System Flow : 60.265  
D2 - System Pressure : 48.979  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 60.265  
Safety Margin : 35.013



# Fittings Used Summary

High Tech Fire Protection  
1ST FLOOR SHALOM HOUSE

Page 3  
Date 9/13/13

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zik	Wilkins 950XL	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

High Tech Fire Protection  
1ST FLOOR SHALOM HOUSE

Page 4  
Date 9/13/13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	4.9	8.2	na	14.03	0.05	256	8.2
DP2	-1.0	4.9	8.2	na	14.03	0.05	256	8.2
10	17.0	K = K @ EQ01	8.05	na	14.03			
11	17.0	K = K @ EQ02	8.28	na	14.29			
12	17.0	K = K @ EQ01	9.42	na	15.18			
13	17.0		9.82	na				
14	16.5		12.18	na				
20	17.0	K = K @ EQ01	11.49	na	16.77			
21	17.0		11.92	na				
22	17.0		12.19	na				
BA	17.0		14.56	na				
BB	16.5		16.19	na				
BC	16.5		22.46	na				
BD	6.5		29.45	na				
BE	6.5		32.2	na				
BF	6.5		35.5	na				
BG	3.0		40.32	na				
BASE	0.0		47.92	na				
HOSE	0.0		51.14	na				
TEST	5.0		48.98	na				

The maximum velocity is 14.66 and it occurs in the pipe between nodes 13 and 14

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
1ST FLOOR SHALOM HOUSE

Page 5  
Date 9/13/13

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	14.03  14.03	1.101 150.0 0.0352	1N	7.0 0.0 0.0	1.000 7.000 8.000	8.200 -0.433 0.282			K Factor = 4.90  Vel = 4.73	
	0.0 14.03					8.049			K Factor = 4.95	
DP2 to EQ02	14.03  14.03	1.101 150.0 0.0353	1O	5.0 0.0 0.0	1.000 5.000 6.000	8.200 -0.433 0.212			K Factor = 4.90  Vel = 4.73	
	0.0 14.03					7.979			K Factor = 4.97	
10 to 11	14.03  14.03	1.101 150.0 0.0353		0.0 0.0 0.0	6.400 0.0 6.400	8.049 0.0 0.226			K Factor @ node EQ01  Vel = 4.73	
11 to 13	14.29  28.32	1.101 150.0 0.1296	1O	5.0 0.0 0.0	6.900 5.000 11.900	8.275 0.0 1.542			K Factor @ node EQ02  Vel = 9.54	
	0.0 28.32					9.817			K Factor = 9.04	
12 to 13	15.18  15.18	1.101 150.0 0.0409	1O	5.0 0.0 0.0	4.750 5.000 9.750	9.418 0.0 0.399			K Factor @ node EQ01  Vel = 5.12	
13 to 14	28.32  43.5	1.101 150.0 0.2864	1N	7.0 0.0 0.0	0.500 7.000 7.500	9.817 0.217 2.148			Vel = 14.66	
	0.0 43.50					12.182			K Factor = 12.46	
14 to 22	43.50  43.5	1.394 150.0 0.0908		0.0 0.0 0.0	2.500 0.0 2.500	12.182 -0.217 0.227			Vel = 9.14	
	0.0 43.50					12.192			K Factor = 12.46	
20 to 21	16.77  16.77	1.101 150.0 0.0491	1N	7.0 0.0 0.0	1.750 7.000 8.750	11.492 0.0 0.430			K Factor @ node EQ01  Vel = 5.65	
21 to 22	0.0  16.77	1.101 150.0 0.0491	1O	5.0 0.0 0.0	0.500 5.000 5.500	11.922 0.0 0.270			Vel = 5.65	
22 to BA	43.49  60.26	1.394 150.0 0.1659	1O	6.0 0.0 0.0	8.300 6.000 14.300	12.192 0.0 2.373			Vel = 12.67	
BA to BB	0.0  60.26	1.394 150.0 0.1659	1N	8.0 0.0 0.0	0.500 8.000 8.500	14.565 0.217 1.410			Vel = 12.67	
BB to BC	0.0  60.26	1.394 150.0 0.1659	3N	24.0 0.0 0.0	13.800 24.000 37.800	16.192 0.0 6.272			Vel = 12.67	
BC to BD	0.0  60.26	1.394 150.0 0.1659	1N	8.0 0.0 0.0	8.000 8.000 16.000	22.464 4.331 2.655			Vel = 12.67	

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
1ST FLOOR SHALOM HOUSE

Page 6  
Date 9/13/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BD to BE	0.0 60.26	1.682 120.0 0.1004	1E 4.95 1T 9.9	12.500 14.850	29.450 0.0				
			0.0	27.350	2.747		Vel = 8.70		
BE to BF	0.0 60.26	1.682 120.0 0.1005	2E 9.9	23.000 9.900	32.197 0.0				
			0.0	32.900	3.306		Vel = 8.70		
BF to BG	0.0 60.26	1.682 120.0 0.1003	1Fsp 0.0	3.000 0.0	35.503 4.516			* Fixed loss = 3	
			0.0	3.000	0.301		Vel = 8.70		
BG to BASE	0.0 60.26	2.157 120.0 0.0300	1Zik 0.0	2.000 0.0	40.320 7.536			* Fixed loss = 6.237	
			0.0	2.000	0.060		Vel = 5.29		
BASE to HOSE	0.0 60.26	1.917 150.0 0.0352	1G 1.047 1E 5.235	75.000 16.752	47.916 0.0				
			1T 10.47	91.752	3.226		Vel = 6.70		
HOSE to TEST	0.0 60.26	12.46 140.0 0.0	1G 9.829 1E 44.231	375.000 152.352	51.142 -2.166				
			1T 98.292	527.352	0.003		Vel = 0.16		
	0.0 60.26				48.979		K Factor = 8.61		