Portland, Maine



Planning & Urban Development Department

Director of Planning and Urban Development Jeff Levine

> Inspection Services, Director Tammy M. Munson

August 7, 2015

WARING PAUL & 529 BRIGHTON AVE PORTLAND, ME 04102

## CBL: 184 E003001 Located at: 529 BRIGHTON AVE

## Certified Mail 7010 1870 0002 8136 8909

Dear Mr. Waring,

An evaluation of the above-referenced property on 08/07/2015 shows that the structure fails to comply with Chapter 6.Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within 30 days of the date of this notice. A re-inspection of the premises will occur on 09/07/2015 at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Code Enforcement Officer (207) 874-8789

CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

> 389 Congress Street Portland, Maine 04101

## **Inspection Violations**

Owner/Manager WARING PAUL &				Inspector Chuck Fagone		Inspection Date
						8/7/2015
Location		CBL		Status		Inspection Type
529 BRIGHTON AVE		184 E003001		Re-Inspect 30 Days		Complaint-Bldg w/o pmt & structu
Code	In	t/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108. (d)	E	xterior			Deck	
Violation:	STAIRWAYS, STAIRWELLS, STAIRS AND PORCHES					
	Every inside and outside stairway, stairwell, stairs, and porch and any appurtenances thereto shall be structurally sound, in good repair, and safe to use.					
Notes:	The front deck needs repairs to ensure that the steps, decking and railings are all structurally sound					
Comments:	Deck appears to be unsafe, please develop a plan of action and inform this office within 30 days.					