

Legalization Inspection Form

Date: 3/29/2017

Address: 572 BRIGHTON AVE (570 ON BUILDING)

Legal Use: Retail, offices and Four dwelling units

Proposed Use: Retail, office; and Five dwelling units

Basement

- Fire Door: Needs another Fire Door From office space to Basement
- Detection: _____
- Sprinkler Head: _____

Notes: Needs Graspable Handrail.

Unit 1-E

- Fire Door: _____
- Detection: _____

Notes: was ok

Unit 1-W

- Fire Door: _____
- Detection: _____

Notes: Bathroom Bottom Sash Needs Tempering

Unit 2-E

- Fire Door: _____
- Detection: Update Smoke Living Room

Notes: Kitchen GFI outlets

Unit 3

- Fire Door: _____
- Detection: CO Combo Hallway,

Notes: GFI outlets kitchen

Unit ____

- Fire Door: _____
- Detection: _____

Notes: Outside Stairs need Gasparillo Handrail.

Unit ____

- Fire Door: _____
- Detection: _____

Notes: _____

Overall Pass _____ Fail _____ Follow up Required _____