

ELECTRICAL PERMIT

City of Portland, Me.



874 8703

To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date February 18, 2009
 Permit # 2009-4096
 CBL# 185-6-004

LOCATION: 68 Wolcott St METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER Josh Woyner
 TENANT _____ PHONE # 831-4545

TOTAL EACH FEE

OUTLETS		Receptacles		Switches		Smoke Detector	.20
FIXTURES		Incandescent		Fluorescent		Strips	.20
SERVICES	/	Overhead		Underground		TTL AMPS <800	15.00
		Overhead		Underground		>800	25.00
Temporary Service		Overhead		Underground		TTL AMPS	25.00
							25.00
METERS	/	(number of)					1.00
MOTORS		(number of)					2.00
RESID/COM		Electric units					1.00
HEATING		oil/gas units		Interior		Exterior	5.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens	2.00
		Insta-Hot		Water heaters		Fans	2.00
		Dryers		Disposals		Dishwasher	2.00
		Compactors		Spa		Washing Machine	2.00
		Others (denote)					2.00
		Air Cond/win					3.00
		Air Cond/cent				Pools	10.00
MISC. (number of)	X	HVAC		EMS		Thermostat	5.00
		Signs					10.00
		Alarms/res					5.00
		Alarms/com					15.00
		Heavy Duty(CRKT)					2.00
		Circus/Carnv					25.00
		Alterations					5.00
		Fire Repairs					15.00
		E Lights					1.00
		E Generators					20.00
PANELS		Service		Remote		Main	4.00
TRANSFORMER		0-25 Kva					5.00
		25-200 Kva					8.00
		Over 200 Kva					10.00
						TOTAL AMOUNT DUE	
						MINIMUM FEE/COMMERCIAL	55.00
						MINIMUM FEE	45.00

185-K-4

DEPT. OF PERMITS
 CITY OF PORTLAND
 FEB 18 2009
 RECEIVED

CONTRACTORS NAME Jeff Woyner MASTER LIC. # MS60019434
 ADDRESS South Ridge Rd Scarborough, ME LIMITED LIC. # _____
 TELEPHONE 415-5802

SIGNATURE OF CONTRACTOR _____

ELECTRICAL INSTALLATIONS

INSPECTION: Service 03/12/09 by MEP
 Service called in _____
 Closing-in _____ by _____

Permit Number _____
 Location _____
 Owner _____
 Date of Permit _____
 Final Inspection _____
 By Inspector _____

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

DATE:

REMARKS:

03/10/09 Needs to upgrade Grounding system
 300 A total service entrance 1/2 on 2
 water pipe.
 Needs re-inspection

MEP

Handwritten notes and scribbles on the right side of the page.

CONTRACTOR'S NAME: _____
 ADDRESS: _____
 TELEPHONE: _____
 MASTER LIC. # _____ LIMITED LIC. # _____

SIGNATURE OF CONTRACTOR _____