

City of Portland, Maine
Inspections Division
Violations Report

Appointment Date Between 1/1/2016 And 1/1/2018

Dist. #	Sch. Date Contact:	CBL	Appl. Type Inspector	Schedule Type Comments	Appl #	Location
HSL Yr 2018	06/28/2016 Toner Bruce M & Sharmon A 1263-1265	186 A001001	Fire Prevention Daniel Thompson	FP Routine Inspection Inspections from Naviline Fire Inspections		1263 CONGRESS ST

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 70- Article 110.12 B-	Exposed Wiring Connections basement	Open				<input type="checkbox"/>	
NFPA 70- 91.25	Missing Box Covers basement	Open				<input type="checkbox"/>	
NFPA 1, Chapter 10 -	Hibachi Or Grill On Balcony first floor deck	Open				<input type="checkbox"/>	

Total Listed: 1