Portland, Maine



Yes. Life's good here.

March 14, 2016

E5 HOLDINGS LLC

935 WESTBOURNE DR # 105

WEST HOLLYWOOD, CA 90069

CBL: 186 A022001

Located at 48 WHITNEY AVE

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager E5 HOLDINGS LLC				Inspector Christopher Goodall		Inspection Date 3/11/2016	
Location 48 WHITNEY AVE		CBL 186 A022001		Status Failed		Inspection Type Fire Company-FP Routine Inspec	
Code	lni	/Ext	Floor	Unit No.	Area	Compliance Date	
1) 69.25 Violation :						UNIT/SUITE NUMBERS NOT MARKED; G NUMERALS.	
Notes:	4.6.2 THE FIRST NUMERAL OF EACH RESIDENTIAL UNIT SHALL BE THE FLOOR DESIGNATION. UNIT NUMBERS NEED TO BE MARKED ON INTERIOR DOORS						
2) 80.56							
Violation:	NFPA 101- 7.2.8.5.1 HANDRAILS REQUIRED ON STAIRS; ALL FIRE ESCAPE STAIRS SHALL HAVE WALLS OR GUARDS AND HANDRAILS ON BOTH SIDES IN ACCORDANCE WITH 7.2.8.4.1 (B).						
Notes:	FRONT STAIRWELL						
3) 55.20							
Violation:	NFPA 101- 31.3.3.2 INTERIOR FINISH; INTERIOR WALL AND CEILING FINISH MATERIALS COMPLYING WITH 10.2 SHALL BE PERMITTED AS FOLLOWS: (1) EXIT ENCLOSURES- CLASS A OR B (2) LOBBIES AND CORRIDORS- CLASS A OR B (3) OTHER SPACES- CLASS A, B, OR C.						
Notes:	PANELING ON WALLS IN REAR STAIRWELL						
Commonte							

Comments:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

E5 Holdings LLC Defendant

SUMMONS NUMBER:

354534

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 05/09/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 05/09/2016.

Dated: 3/25/6

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Counsel

City of Portland 389 Congress St Portland, ME 04101 207-874-8480