Headers

(1) Garage Door header 112" header made from (2) 2x10s and 1/2" Plywood
(1) Man door header 36" made from (2) 2x10s and 1/2" plywood
(4) Windows 36" Header made from (2) 2x10s and 1/2" Plywood

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/05/15

A12	Garage Cross Section
Date	11/08/14
Scale 3/8"=1'	