Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/05/15

Door and Window Schedule for 52 Bolton St

#	Name	Width	Height	Material	Notes
1	American Craftsman	5’	6’8”	Vinyl	Slider
2					Existing Relocated
3	Hancock Classic	3’4”	5’4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51 **Egress**
4	Hancock Classic	2’ 8”	4’	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51
5	Hancock Classic	3’4”	5’4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51 **Egress**
6		2’ 8”	6’ 8”	Wood interior	
7		2’ 8”	6’ 8”	Wood interior	
8		2’ 8”	6’ 8”	Wood interior	
9	Not Used				
10					Existing Exterior
11		9’	8’		Garage Door
12	Hancock Classic	2’ 8”	3’ 4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51
13	Hancock Classic	2’ 8”	3’ 4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51
14	Hancock Classic	2’ 8”	3’ 4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51
15	Hancock Classic	2’ 8”	3’ 4”	White Vinyl	UFactor: 0.26 SHG: 0.29 VLT: 0.51