

•
•
•
•
•
•
•

facsimile transmittal

To: Tim or Judy -- Mainewide **From:** Mike Nugent
Fax: 207-622-7528 **Date:** March 5, 2002
Phone: 800-452-1940 **Pages:** 1
Re: 110 Whitney Ave. 186A A018 **CC:** Mr. & Mrs Jones

Urgent For Review Please Comment Please Reply Please Recycle



Notes: In reviewing the permit for the above property, please forward the following details:

- 1. Footing Dimensions
- 2. Foundation wall thickness Foundation cross section
- 3. Size of anchor bolts
- 4. The 6" x 10" headers in the "open roof system" are under designed (See Table 502.5(1) in the 2000 I.R.C.
- 5. Step details from existing house
- 6. Header details where omitted
- 7. Egress window replacement schedule in existing house (Hardware included)
- 8. Electrical detail
- 9. Plumbing plan for "both rooms"
- 10. Foundation Drilling and Pinning detail
- 11. Steps stairs and landing details for the exterior doors.
- 12. Demo Permit Must be obtained prior to issuance of this permit due to lot coverage


limitation.



•
13. Structural Steel loading specs from the manufacturer and installation /framing detail.

•
•
•
•
•
•





• • • • • • • •



• • • • • • • • • • • • • • • • • • • •