CITY OF PORTLAND, MAINE
389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

September 21, 1988

Mr. Francis G. Connolly
183 Whitney Avenue
Portland, ME

Dear Sir:

Your application to construct 3rd floor exit has been reviewed and a permit is herewith issued subject to the following requirements:

The required risers shall not exceed 8" tread. Treads may be 11".

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

P. Samuel Hoffses

P. Samuel Hoffses
Chief, Inspection Services

PSH/jg

cc: L.E. Gallina