

COMMENTS

3-22-99 Did pre construction with Doug Stoll By Phone went over list of conditions and when to call me for inspection (TR)

3-31-99 Doug called and The Footers are being poured he will call when ready for backfill (TR)

4-5-99 went by ok on backfill Drain tile in place with stone and Filter Fabric coating on wall (TR)

3-17-99 - checked FRAMING of addition - everything looks good - will have electrical inspector out soon and then will close in. Tom M. / Tom R. / Marland W  
~~Stud~~

2/24/04 - Work has been completed & appears to meet conditions of the permit. Tom M

Close out

CBC # 186-AC-5

permit # 990245

Inspection Record

Type	Date
Foundation:	_____
Framing:	_____
Plumbing:	_____
Final:	_____
Other:	_____