

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: * 1335 Congress St		Owner: Angellio's Inc.		Phone:		Permit No:	
Owner Address:		Lessee/Buyer's Name: * Esposito's		Phone:		BusinessName:	
Contractor Name: Bailey Sign		Address: 9 Thomas Dr Westbrook, ME		Phone: 04092		Permit Issued:	
Past Use: Restaurant		Proposed Use: Same		COST OF WORK: \$		PERMIT FEE: \$ 31.00	
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
Proposed Project Description: Erect Signage				Signature:		Signature:	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Zone: CBL: 187-A-001	
Permit Taken By: Mary Gresik		Date Applied For: 23 June 1997		Signature:		Date:	
						Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**Zoning Appeal**

Variance  
 Miscellaneous  
 Conditional Use  
 Interpretation  
 Approved  
 Denied

**Historic Preservation**

Not in District or Landmark  
 Does Not Require Review  
 Requires Review

**Action:**

Approved  
 Approved with Conditions  
 Denied

Date: \_\_\_\_\_

**CERTIFICATION**


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT *Bernadette Danis* ADDRESS: DATE: 23 June 1997 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT



SIGNAGE

PLEASE ANSWER ALL QUESTIONS

Address: \_\_\_\_\_ Zone: R-5

Owner: \_\_\_\_\_ Assessors #: \_\_\_\_\_

Applicant: \_\_\_\_\_

Single Tenant Lot?: Yes \_\_\_\_\_ No \_\_\_\_\_

Multi Tenant Lot?: Yes \_\_\_\_\_ No \_\_\_\_\_

Freestanding (Ext pole sign)? Yes \_\_\_\_\_ No \_\_\_\_\_ Dimensions \_\_\_\_\_

More than (1) one sign?: Yes \_\_\_\_\_ No \_\_\_\_\_ Dimensions \_\_\_\_\_

Bldg Wall Sign (att to bldg)? Yes \_\_\_\_\_ No \_\_\_\_\_ Dimensions \_\_\_\_\_

List all existing signage and their dimensions:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Lot Frontage(feet): \_\_\_\_\_ Tenant Frontage(feet): \_\_\_\_\_

AWNINGS

Awning?: Yes \_\_\_\_\_ No \_\_\_\_\_ Is Awning Backlit?: Yes \_\_\_\_\_ No \_\_\_\_\_

Is there any communication, message, trademark or symbol on awning? \_\_\_\_\_

Height of Awning?: \_\_\_\_\_

PLEASE NOTE: Approvals for signs on the Public Sidewalk and temporary signs come under different requirements and regulations.

ALSO: See reverse side for additional information, requirements and materials needed for signage application submittal.

300

## BUILDING PERMIT REPORT

DATE: 30 June 97 ADDRESS: 1335 Congress ST  
REASON FOR PERMIT: To erect signage  
BUILDING OWNER: Angello's Inc.  
CONTRACTOR: Barley Sign  
PERMIT APPLICANT: Bernadette Paris APPROVAL: X1 \*27 \*28 ~~RENTED~~


### CONDITION(S) OF APPROVAL

- X 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42" , except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
9. Headroom in habitable space is a minimum of 7'6".
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's.
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and



# Esposito's RESTAURANT



(1) 4'0" X 3'0" AFRAME SIGN

FRAMING MATERIAL: ALUMINUM  
 FINISH: POLYURETHANE  
 LETTERS: ENAMEL  
 MOUNTING: BRASS  
 FINISH: POLYURETHANE  
 MOUNTING: BRASS

**SPECIAL INFORMATION**

**PLEASE NOTE:**  
 THIS SIGN IS THE PROPERTY OF THE COMPANY AND IS TO BE USED ONLY FOR THE COMPANY'S BUSINESS. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

**Customer:**  
**ESPOSITO'S**  
 1000 CONGRESS STREET  
 PORTLAND, ME  
 SALES: R. SENN  
 PHONE: L.W. MERRIFIELD  
 ADDRESS: 1000 CONGRESS STREET  
 PORTLAND, ME 04102

**DATE:** 11/2/97

**QUANTITY:** 1

**PRICE:** 617.97

**TOTAL:**

**ORDER NO.:** 3582 A



**Bailey sign**  
 9 Thomas Drive  
 Col. Westbrook Executive Park  
 Westbrook, ME 04090  
 207-741-2843 FAX: 207-741-2844  
 © COPYRIGHT 1997

DEPT. OF BUILDING INSPECTION  
 CITY OF PORTLAND, ME  
 JUN 23 1997

INTERNALLY ILLUMINATED SIGN  
 11' X 17' X 1/2" ALUMINUM SIGN  
 11' X 17' X 1/2" ALUMINUM SIGN  
 11' X 17' X 1/2" ALUMINUM SIGN  
 11' X 17' X 1/2" ALUMINUM SIGN

UL #



PLEASE NOTE:  
 THIS SIGN IS DESIGNED TO BE USED WITH A 120VAC, 60HZ POWER SOURCE. THE SIGN IS NOT TO BE USED WITH A 240VAC POWER SOURCE. THE SIGN IS NOT TO BE USED WITH A 12VDC POWER SOURCE. THE SIGN IS NOT TO BE USED WITH A 5VDC POWER SOURCE. THE SIGN IS NOT TO BE USED WITH A 1.5VDC POWER SOURCE.

**Bailey sign**  
 3 Thomas Drive  
 Col. Westbrooke Executive Park  
 Westbrook, ME 04092  
 207/733-2613 / 1-800-549-5844  
 © COPYRIGHT 1997

CUSTOMER:  
 ESPOSITO'S  
 COMPANY:  
 CONGRESS STREET  
 PORTLAND, ME  
 SALESPERSON: R. BENN

2767N E. L.W. MERRIFIELD

DATE: 6/17/97  
 ORDER # D-854  
 ORDER # 6/17/97



ORDER # 03882 A