

COMMENTS

12/16/99 Porch finished - rail heights + distance openings OK - 2 steps with one at 11<sup>1/4</sup> inch rise - no handrails or guardrails in place. - 20 inch height from ground surface to top of decking. Call owner or write memo

3/13/03 Close out

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____