



Department of Permitting and Inspections

Air Velocity within the duct system 3000 CFM .50 SP

Grease accumulation prevention system: NA

Cleanouts: N/A Duct less than 10'

Grease Duct enclosure: 3m 615<sup>+</sup> grease duct wrap

Exhaust Termination: Roof X Wall \_\_\_\_\_

Fire Suppression System: Other

Exhaust fan mounting and clearance from the roof / wall or Combustibles:  
18" off roof 40 AT TOP OF fan 10' away from combustibles and opens

Exhaust fan distance from property lines: 10'

Exhaust fan distance from other vents or openings: 10'

Exhaust fan distance from adjacent buildings: 10'

Exhaust fan height above adjoining grade: 15'

3. Hood Specs

Style of Hood: Canopy

Type of Filter: Grease baffles

Height of filter above nearest cooking surface: 36"

Capacity of hood CFM: 3000 CFM

Make up Air system description and capacity:  
met fan on roof to bring in 2400 CFM. vent through Plenum, PFP