

MADDEN PLUMBING & HEATING, LLC

205 Burnham Road, Gorham, ME 04038

Office 207-221-2991 Cell 207-650-6761

06/05/2015

Mr. Douglas Morin
Code Enforcement Officer
City of Portland, Maine
389 Congress Street
Portland, ME 04101

Dear Mr. Morin;

Regarding 1283 Congress Street – the plumbing was air tested and held pressure for over fifteen minutes under five pounds of pressure.

Regards,



George Madden
Owner
Madden Plumbing & Heating, LLC