

PINKHAM ENVIRONMENTAL INC.
P.O. BOX 405
BOOTHBAY, MAINE 04537

CERTIFICATE OF RE-OCCUPANCY

CLIENT: *Abatement Professionals*

PROJECT: *90 FRANCES STREET*

PEI #: *17-2086*

BUILDING: *RES. DENCE*

WORK AREA: *1st Floor*

The airborne fiber concentration in the work area has been determined to be below the Environmental Protection Agency's recommended safe level for re-occupancy of 0.01 f/cc. The Pinkham Environment representative has declared this area available for re-occupancy by unprotected personnel on the *21st* day of *Dec* at *1100* hours.


[field technician signature]
PINKHAM ENVIRONMENTAL INC.

Date: *12-21-17*