



Gregory Gilbert <ggilbert@portlandmaine.gov>

Re: BP# 2017-00533_40 Dirigo Street

1 message

Ryan <lom11p34@gmail.com>
To: Gregory Gilbert <ggilbert@portlandmaine.gov>

Thu, May 25, 2017 at 10:32 PM

Hi Greg,

40 DIRIGO ST. – ADDITIONAL INFORMATION REQUESTED ON 5-25-17

The window sizes on the front of the porch for the two double hung windows would be 34 1/4" x 53 1/4" to match the existing windows on the first floor of the home. The two awning windows would be 17 1/2" x 47 1/2".

The porch floor is pre-existing (it is a fully covered front porch with the ceiling being part of the currently existing roof). I want to frame in above the pre-existing vinyl sided 2'x6' railing/knee walls with 2 x 6 lumber and add sheathing, windows and vinyl siding to match existing. The sheathing I would like to use for the existing walls would be 15/32" x 4' x 8' Douglas Fir plywood.

Thank you for your help. Please let me know if you require any additional information.

Sincerely,

Ryan Lombard

On Thu, May 25, 2017 at 2:31 PM, Gregory Gilbert <ggilbert@portlandmaine.gov> wrote:
Good Afternoon Ryan,

I hope all is well.

I am contacting you in regard to the permit application for 40 Dirigo Street.

Please Provide the sizes of the windows and doors being added to the 3 season porch.

please provide the sizes of sheath that will be added top the floor and exterior walls

If you have any questions or concerns, please let me know.

Best Regard,

Greg Gilbert

Code Enforcement Officer /
Plan reviewer
Permitting and Inspections Department
City of Portland
389 Congress St. Rm 315
Portland, ME 04101
(207) 874-8700

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.



40 Dirigo St. - Additional Requested Information 5-25-17.pdf

317K