

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

BERRY GEORGE P & AMY J JTS

Located at

41 STEVENS AVE

PERMIT ID: 2017-01900

ISSUE DATE: 12/21/2017

CBL: 188 A032001

has permission to **2nd Amendment to 2017-01206. Convert proposed enclosed front porch to open porch design.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.	A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	---

N/A

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group:

Type:

Single family Residence

Porch

2009 IRC / MUBEC

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-01900	Date Applied For: 12/04/2017	CBL: 188 A032001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same. Single Family.		Proposed Project Description: 2nd Amendment to 2017-01206. Convert proposed enclosed front porch to open porch design.		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 12/06/2017</p> <p>Note: R-3 zone Ok to Issue: <input checked="" type="checkbox"/></p> <p>It appears revised porch would be a slight expansion into the front setback (about 2' more than current stoop). This would more than meet the approximate average abutters' front setback of 15'.</p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) .All conditions from previous permits for this project are still in effect with the issuance of this permit. 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 				
<p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 12/21/2017</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) All construction shall comply with City Code Chapter 10. 2) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 3) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 5) .All conditions from previous permits for this project are still in effect with the issuance of this amendment. 				