

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Seven Dirigo St		Owner: Maade C Swenson	Phone: 773-5625	Permit No: 970557
Owner Address: Seven Dirigo St- Portland ME 04102		Lessee/Buyer's Name:	Phone:	<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED JUN - 9 1997 CITY OF PORTLAND </div>
Contractor Name: 02000		Address:	Phone:	
Past Use: l-fan dwlg	Proposed Use: l-fan w deck	COST OF WORK: \$ 2500	PERMIT FEE: \$ 35	Zone: CBL R-3 188--B-010-001 Zoning Approval: <i>[Signature]</i> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type:	
Proposed Project Description: construct deck		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		
Permit Taken By: L Chase		Date Applied For: 5/29/97		

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS
PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

[Signature]
ADDRESS:
DATE: 5/29/97
PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: 5/29/97

5

CEO DISTRICT


D Jordan

COMMENTS

3-26-98 No Railings on deck

4/7/00 - Deck is up and appears finished - rails look ok and from the side of house it appears to be finished.

Close out



Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

Applicant: Meade C. Swenson

Date: 6/4/97

Address: 7 Divigo St

C-B-L: 100-B-10

CHECK-LIST AGAINST ZONING ORDINANCE

Date - Existing 1939

Zone Location - R-3

Interior or corner lot -

Proposed Use/Work - construct deck 14' x 18'

Sewage Disposal -

Lot Street Frontage -

Front Yard - 25' req - 29' shown

Rear Yard - 8' req - 10' shown

Side Yard -

Projections -

Width of Lot -

Height -

Lot Area -

6,500 sq ft

Lot Coverage/ Impervious Surface - 25% MAX

1625 sq ft MAX

Area per Family -

Off-street Parking -

8 x 12 = 96 sq ft

Loading Bays -

22 x 20 = 616 sq ft

Site Plan -

10 x 32 = 320 sq ft

Shoreland Zoning/ Stream Protection -

5 x 12 = 60 sq ft

Flood Plains -

1092 sq ft

New 18' x 14'

252 sq ft

1344 sq ft

- BUILDING PERMIT REPORT


DATE: 5 June 97 ADDRESS: 7 Dirigo ST
REASON FOR PERMIT: To construct 14'x18' deck
BUILDING OWNER: Meade C. Swenson
CONTRACTOR: owner
PERMIT APPLICANT: ↑ APPROVAL: *1,*2,*7,*9 ~~DENIED~~

CONDITION(S) OF APPROVAL

- ~~X~~1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- ~~X~~2. Before concrete for foundation is placed, approvals from the ~~Development Review Coordinator~~ and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
- ~~X~~7. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42" , except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
8. Headroom in habitable space is a minimum of 7'6".
- ~~X~~9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
10. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
12. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's.
14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
18. The Sprinkler System shall maintained to NFPA #13 Standard.
19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
25. All electrical and plumbing permits must be obtained by a Master Licensed holders of their trade.
26. _____
27. _____
28. _____


P. Samuel Hoffses, Chief of Code Enforcement

cc: Lt. McDougall, PFD
Marge Schmuckal

THIS IS NOT A BOUNDARY SURVEY

INSPECTION OF PREMISES

I HEREBY CERTIFY TO DOUGLAS TITLE, ~~HORNER~~ ~~MORTGAGE~~ & ITS TITLE INSURER

7 DIRIGO STREET
PORTLAND, MAINE

Job Number: 202-27
Inspection Date: 04-26-93
Scale: 1" = 20'

The monumentation is set in harmony with current deed description.


The building setbacks are set in conformity with town zoning requirements.

The dwelling does not appear to fall within the special flood hazard zone as delineated by the Federal Emergency Management Agency.

The land does not appear to fall within the special flood hazard zone as indicated on community-panel # 23005, 0013B.

BUYER: HEADE & SIMPSON

SELLER: ROBERT M. & ANNE D. HASKELL



THIS PROPERTY IS SUBJECT TO ALL RIGHTS AND EASEMENTS OF RECORD THOSE THAT ARE EVIDENT ARE SHOWN THIS PLAN MIGHT NOT REVEAL CONFLICTS WITH ABUTTING DEEDS

BRUCE R. BOWMAN, INC.
48 Mill Road
Cumberland, Maine 04021
Phone: (207)829-3959



PLAN BOOK _____ PAGE _____ LOT _____
DEED BOOK _____ PAGE _____ COUNTY CUMBERLAND

THIS PLAN IS NOT FOR RECORDING Drawn by: JHM

BASIC GUIDELINES FOR DECK PERMITS

Materials needed to apply for permit:

- 1) Plot Plan - A Bird's eye view of your property showing where all your buildings are located in relationship to the lot lines and each other. You need to show those distances (the front, rear and sides) in feet.
- 2) Construction Plan - Cross Section. What dimensional lumber/materials are being used and what is their make-up?
- 3) Fee - Based on cost of work labor/materials. 25.00 1st 1,000 worth of work, 5.00 each additional 1,000.

Approx \$2000 => \$25 + \$5 = \$30

The following check-off sheet can be used in most circumstances:

Foundation

- Frost wall, min 4' below grade
- Sone tubes, min 4' below grade, 6" min on footing, hard pan or bedrock
- Other

Sill

6.5' Distance between foundation supports

Joist Size

2x6 2x8 2x10

Joist Span

3 sections: 7', 7', 4'

Distance Between Joists

16"oc 24"oc other

Decking

5/4 other/explain

Stair Construction

10" min tread 7 3/4" max riser

Guard Height

36" 42"

Guards shall be located along open-sided walking surfaces located 15 1/2" above the floor or below grade. Single family - min 36", all others 42", measured vertically above the leading edge of the tread or adjacent walking surface. BOCA 1005.5/1021.2

Balusters

/under 4"

Open guards shall have balusters or be of a solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.