



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/26/13

22

* (1) E-Gress in Master
Bedroom

* (1) E-Gress in Second floor
Bump out

# of windows	location of windows	U Factor
(3) (1) E-gress (1) E-Gress	Master bedroom Master bedroom Second floor bedroom	0.29
(1) door	Master bedroom	
~~~~~		
Insulation will be fiberglass	all walls all ceilings	R-21 R-49
	floor	R-30