

•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Clyde Blackwell **From:** Mike Nugent

Fax: 842-6271 **Date:** December 15, 2003

Phone: 842-6260 **Pages:** 1

Re: 1200 Congress St. (189 A013)

Urgent For Review Please Comment Please Reply Please Recycle



I have reviewed the submissions for Permit #031478 and have the following questions/comments:

- 1) The construction drawings are not stamped.
- 2) Is the exit corridor on the first floor (fig. 1/A1) at least 44 inches in width?
- 3) A statement of special inspections is required for the new steel/concrete and fasteners. (See Section 1705 of the 1999 BOCA Code).
- 4) Tread and riser dimensions for new stairs?
- 5) Floor loads for new systems
- 6) Are the openings in the Guard shown on Fig. A-A2 Less than 4 inches with an ornamental pattern that is not a ladder.

• • • • •