Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/27/17

To: City of Portland, ME – Portland Fire Department

From: Colby Malcolm, Eastern Fire

Re: Norway Savings Bank – 2nd Floor Server Room

Date:4/6/17

Norway Savings Bank is an existing three story office building currently under renovation on the 2nd floor. The entire building is protected by a supervised fully automatic fire sprinkler system and manual fire alarm system. The renovation on the second floor is considered business/office space and sprinkler/fire alarm systems are being modified to accommodate.

The owner wishes to install a new fire suppression system in the second floor server room to protect their high value assets. A new NOVEC 1230 clean agent system will be installed in the room for protection. Integrated cross zoned detection and manual activation shall be integrated into the local releasing panel which is monitored by the building fire alarm system. The owner has also elected to remove wet sprinkler coverage within the protected space.

Please do not hesitate to contact me with any questions. Thank you

Colby Malcolm
Eastern Fire
malcolmcr@easternfiregroup.com
207-784-1507