Location of Construction:	Owner:	[Ph	one:	Permit No:	
1230 Congress St	Olympia Equity			Fernit NO.	
Owner Address:	Lessee/Buyer's Name:		isinessName:	7	
	Double Tree Hotel				
Contractor Name:	Address:	Phone:		Permit Issued:	
Sign Design	·		9-2000		
Past Use:	Proposed Use:	COST OF WORK:	PERMIT FEE:		
Hotel	Sama	\$	\$ 63.30		
HOLET	Same	FIRE DEPT. Appro			
		Denied Denied	d Use Group: Type:	70000 CPI :	
				Zone: CBL: 189-A-014	
Proposed Project Description:	<u>_</u>	Signature:	Signature:	Zoning Approval:	
roposed rojeet Description.			/ITIES DISTRICT (P.A.D.)		
		Action: Appro		J Special Zolle of Reviews.	
		Approved with Conditions: Denied			
Erect Signage 19	1.50 Sq Ft	Defile		J UWetland	
		Signature:	Date:		
Permit Taken By:	Date Applied For:			Site Plan maj Diminor Dmm D	
Mary Gresik	21	July 1997			
				─ Zoning Appeal □ Variance	
1. This permit application does not preclude	the Applicant(s) from meeting applicable S	tate and Federal rules.		☐ Miscellaneous	
2. Building permits do not include plumbing	, septic or electrical work.			Conditional Use	
3. Building permits are void if work is not sta	arted within six (6) months of the date of iss	uance. False informa-			
tion may invalidate a building permit and				□ Approved	
, 51				Denied	
				Historic Preservation	
				□Not in District or Landmark	
				Does Not Require Review	
				Requires Review	
				Action:	
	CERTIFICATION				
I hereby certify that I am the owner of record o					
authorized by the owner to make this applicati				',	
if a permit for work described in the application areas covered by such permit at any reasonabl				Date:	
areas covered by such permit at any reasonable	e nour to enforce the provisions of the code	e(s) applicable to such perm			
XV/ J			744,7000		
Frinch	2~	<u>21 July 1997</u>	11000		
SIGNATURE OF APPLICANT Paul Adl	er ADDRESS:	DATE:	PHONE:		
<i>Y</i>					
RESPONSIBLE PERSON IN CHARGE OF W	ORK, TITLE		PHONE:		
			•		
White	⊢Permit Desk Green–Assessor's Can	ary-D.P.W. Pink-Public F	File Ivory Card-Inspector		

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

SIGNAGE

PLEASE ANSWER ALL QUESTIONS

Address: 1230 (1) Zone: Guity LANES DASSessors #: owner: UIUMDIA 41 Applicant: Ark MAX 34 4 4 126 single Tenant Lot?: Yes No Multi Tenant Lot?: Yes No 🗸 Freestanding (Ext pole sign)? Yes _____ No ____ Dimensions More than (1) one sign?: Yes No / Dimensions Bldg Wall Sign (att to bldg)? Yes V No Dimensions 529 ATTACH 9.15×31=12.5 List all existing signage and their dimensions: 1. Y 6 APPLY - 36. 112. Lot Frontage(feet): Tenant Frontage(feet): AWNINGS Is Awning Backlit?: Yes _____ No _____ Awning?: Yes No Is there any comunication, message, trademark or symbol on awning? Height of Awning?:

PLEASE NOTE: Approvals for signs on the Public Sidewalk and temporary signs come under different requirements and regulations.

ALSO: See reverse side for additional information, requirements and materials needed for signage application submittal.

581 3140" US-ST 1 DiGIN Ś Customer: ERIN CO. Project: DOUBLE TREE AWNING Date: 06-10-97 Approved: Sign Design PROPE 1

ST CEDERS

	.998ж. 29.15-QD (
$\Sigma_{\mathcal{S}}(1,1) \leq_{\mathcal{S}}$		scores :	-
Çeşev.	2/2 C 0111		
άθητετου ο			
Sine - The A			
2015 - Constant Constant	10. 		
₹C 2011	least (46)	diamasions (-)	X 12'
Monte la constante de la const			
Blag to a start	· · · · · · · · · · · · · · · · · · ·	chadusions (
List	Media dimensions:		
· · · · · · · · · · · · · · · · · · ·			
Less and the state of the	Tonant Fr ni s	terbeet):	
	NWNINGS		

Height of the set

PLEASE set on the sublic for and temporary signs occurs to the sublice.

Note a company of the company of the company and the company of th

BUILDING PERMIT REPORT

DATE: 28 July 97 ADDRESS: 1230 Congress ST.	
REASON FOR PERMIT: TO CHECT Signage	
BUILDING OWNER: OLYMPIQ Equity Investors	
CONTRACTOR: Sign Desm	
PERMIT APPLICANT: Pay Allor APPROVAL: *1 *27*28-	DENIED

CONDITION(S) OF APPROVAL

- 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- 3. Precaution must be taken to protect concrete from freezing.
- 4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
- 5. Private garages located <u>beneath habitable rooms</u> in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- 6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
- 7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
- 8. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
- 9. Headroom in habitable space is a minimum of 7'6".
- 10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
- 11. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
- 12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 14. All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self closer's.
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
- 16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and