

# **EASTERN FIRE**

**FIRE SPRINKLER CONTRACTORS AND DESIGNERS**

## **MEMO**

**DATE: 06/22/2017**

**TO: Gerry Leach**

**FROM: James Lemay**

**SUBJECT: Dermatology, Portland Maine**

**Gerry,**

**This memo is to inform you that no hydraulic calculations were performed on the Dermatology project due to the scope of the project which was re-working the existing sprinkler system to accommodate the new floor plan. Pipe sizing is per existing hydraulic calculations.**

**If you have any questions concerning this correspondence feel free to contact me.**

**Sincerely,**

**James Lemay  
System Designer, Eastern Fire Protection**

**TOTAL PAGES: 1**

**207-784-1507 Fax: 207.782.0566  
P.O. Box 1390 Auburn, Maine 04211-1390**