



NOTE:
 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

- KEYED NOTES:**
- ① MOUNT RECEPTACLES 42" AFF TO CENTER OF DEVICE.
 - ② MOUNT RECEPTACLES 18" AFF BELOW OR INSIDE CASEWORK. CASEWORK TO HAVE GROMMETS FOR POWER CORDS TO BE RUN THROUGH.
 - ③ PROVIDE POWER FOR AUTOMATIC DOOR OPERATORS. PROVIDE JUNCTION BOX FOR PAD OPERATORS AND WIRING FROM PUSH PADS TO DOOR OPERATOR. COORDINATE W/ ARCHITECT FOR EXACT LOCATION OF PUSH PADS.
 - ④ RE-FEED PANELBOARD EESP1 AS INDICATED ON ONE-LINE DIAGRAM. REMOVE EXISTING 100A TRANSFER SWITCH. RE-FEED 10 LIGHTING CIRCUITS IN PANELBOARD EESP1 FROM NEW LIFE SAFETY PANELBOARD LS1A. IN PANELBOARD EESP2 RE-FEED 2 LIGHTING CIRCUITS FROM PANELBOARD LS1B. FIELD VERIFY THAT ALL EMERGENCY LIGHTING IS FED FROM LIFE SAFETY BRANCH OF ELECTRICAL SYSTEM.

0	ISSUED FOR PERMITTING	5-20-03
REV.	DESCRIPTION	DATE

ISSUED FOR PERMITTING
5-20-03

CURRENT ISSUE STATUS:



ORTHOPAEDIC ASSOCIATES
SEWALL STREET EXPANSION
 PROJECT: 22 SEWALL STREET, PORTLAND, MAINE

FIRST FLOOR
POWER PLAN

SHEET TITLE:	1/8"=1'-0"	DATE:	5-20-03
PROJECT MANAGER:	DJT	GRAPHIC SCALE:	0" 1"
JOB CAP/DRAWN:	LAM	A/E OF RECORD:	DJT
SMRT CAD FILE:	EP101-03018	SHEET No.	EP101
PROJECT No.	03018		

A1 FLOOR PLAN
 1/8"=1'-0"