



**NOTE:**

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

**KEYED NOTE:**

① MOUNT HEAT DETECTOR WITHIN 24" OF SPRINKLER HEAD. IF MORE THAN ONE SPRINKLER HEAD IS INSTALLED PROVIDE ADDITIONAL HEAT DETECTORS AS REQUIRED TO MEET DISTANCE REQUIREMENTS.

REV.	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING	5-20-03

**ISSUED FOR PERMITTING**  
**5-20-03**

CURRENT ISSUE STATUS:



ORTHOPAEDIC ASSOCIATES  
SEWALL STREET EXPANSION  
PROJECT: 22 SEWALL STREET, PORTLAND, MAINE

**BASEMENT**  
**FIRE ALARM PLAN**

SHEET TITLE:	SCALE: 1/8"=1'-0"	DATE: 5-20-03
PROJECT MANAGER: DJT	JOB CAP/DRAWN: LAM	GRAPHIC SCALE: 0" 1"
A/E OF RECORD: DJT	SMRT CAD FILE: FA100-03018	SHEET No. FA100
PROJECT No. 03018		

A1 FLOOR PLAN

1/8"=1'-0"