FOUNDATION PLAN
1/4"=1'-0"

TOP OF NEW SLAB ELEV. TO MATCH TOP OF EXIST. SLAB ELEV = 0'-0" (EXCEPT AT 1 1/2"± RECESSED MRI SLAB).

ALL CONCRETE SLABS ARE FIBER-REINFORCED.

TOP OF WALL AT MRI SLAB
1/2"=1'-0"
COORD. BRICK SHELF EL WITH EXIST. BRICK COURSING. COORD. SLAB EL WITH MRI SUPPLIER

SECTION 1
1/2"=1'-0" S100

COORD. BRICK SHELF EL WITH EXIST. BRICK COURSING.

SECTION 3
1/2"=1'-0" S100

SECTION 2
1/2"=1'-0" S100

SEE SECTION 1 FOR ADDITIONAL INFORMATION

SECTION 4
1/2"=1'-0" S100

6" SLAB AT MRI.
TOP OF SLAB AT MRI EL = (-) 1 1/2"±

TYP SLAB INTERFACE AT MRI
3/4"=1'-0"

SECTION 5
1/2"=1'-0" S100

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/16/13
Planner: Benjamin Wallace

PDT ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

22 Oakmont Drive
Old Orchard Beach ME
04064-4121
Tel 207.934.8038
Fax 207.934.8039
STRUCTURAL DESIGN CONSULTING

OA Centers for Orthopedics
33 Sewall Street, Portland Maine

STATE OF MAINE
DAVID TETREAULT
4640
PROFESSIONAL ENGINEER

JOB NO.
12126

DRWN. CHK
DJT

SCALE:
AS NOTED

ISSUE
BID & PERMIT SET
MARCH 8, 2013

TITLE
Foundation Plan and Sections

SHEET
S100