SECTION 1
1"=1'-0" S200

SECTION 2
1"=1'-0" S200

SECTION 3
1"=1'-0" S200

SECTION 4
1"=1'-0" S200

SEE SECTION 1 FOR ADDITIONAL INFORMATION

ROOF FRAMING PLAN
1/4"=1'-0"

ROOF DECK IS PAINTED 22 GAGE, 1 1/2" TYPE B STEEL DECK.

ALL LIGHTGAGE STEEL IS BY DIETRICH INDUSTRIES, INC OR APPROVED ALTERNATE.

NEW COLUMN SCHEDULE				
COLUMN MARK	SIZE	BOT. OF BASE PL ELEV.	BASE PL TYPE	TOP OF COLUMN ELEV.
8.3-H.9 8.4-H.9	HSS4x4x3/16	(-) 0'-7"	A	9'-10"
8.3-H.1	W12x40	(-) 0'-9"	B	12'-5 1/4"

TYPICAL ANCHOR ROD DETAILS
3/4"=1'-0"

CANOPY FRAMING PLAN
1/4"=1'-0"

TYPE A
THICKNESS = 1/2"

TYPE B
THICKNESS = 7/8"
EDGE DIST = 1 1/2" UNO

DETAIL A
3/4"=1'-0"

PDT ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

STRUCTURAL DESIGN CONSULTING
22 Oakmont Drive
Old Orchard Beach ME
04064-4721
Tel 207.934.8038
Fax 207.934.8039

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/16/13
Planner: Benjamin Wallace

OA Centers for Orthopedics
33 Sewall Street, Portland Maine

STATE OF MAINE
DAVID TETREAULT
6840
LICENSED
STRUCTURAL ENGINEER

JOB NO.
12126

DRWN. CHK
DJT

SCALE:
AS NOTED

ISSUE
BID & PERMIT SET
MARCH 8, 2013

TITLE
Roof Framing Plan and Sections

SHEET
S200