Legend

SD	Duct Smoke Detector
SD	Smoke Detector
H	Horn/Strobe
S	Strobe
F	Pull Station
E	Emergency
EX	Existing
1	Replace existing strobes and rewire to connect to RB ALLEN FA System. Strobes are currently fed from pre action system.
2	Smokes are provided with and monitored by the pre action system. Supplied by Others.

Note: New FA devices to be added to existing system.

Note: Emergency Lighting to be fed from Emergency Generator

Scale 1/4" = 1'

STATE OF MAINE
WILLIAM S. RENNETT
No. 12919
LICENSED
PROFESSIONAL ENGINEER

CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 7/29/2013

49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

Orthopedic Associates
MRI Renovation
33 Sewall St Portland, ME

JOB NO.

DRWN. CHK

SCALE:

ISSUE
1/4" = 1'

TITLE
Fire Alarm

SHEET
E-103