OA Centers for Orthopedics
33 Sewall Sreet
Portland, Maine

Click Here to Ret
Bill of Material/Ir

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/29/13

System Narrative

In the event of an alarm from an actuated device, the following shall occur: (Devices reporting an alarm: Manual Station, Pre-Action System Activation)

1) Notify the Central Station via Digital Alarm Communicator (DACT).

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel.

3) Activate the exerior Strobe/Beacon

4) Flash all strobe appliance circuits in a synchronized manner until silenced. If Silenced, the strobes shall resound upon receipt of a new alarm.

5) Sound a Temporal Code 3 on all horn units until silenced. If Silenced, the evacuation tone shall resound upon receipt of a new alarm.

In the event of a supervisory condition from an actuated device, the following shall occur: (Devices reporting a supervisory: Pre-Action System Fault)

1) Notify the Central Station via Digital Alarm Communicator (DACT).

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel.

In the event of a system trouble report, the following shall occur:

1) Notify the Central Station via Digital Alarm Communicator (DACT).

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel.