



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/29/13

1 ALARM

ALARM

↓

2 DISPLAY

CURRENT NUMBER OF TIME → EVENT TIME
MESSAGES →

14:55:18	M:001	10:23
1ST FIRE ALARM		407
4 FL SPRINKLER VALVE		
MAINT ROOM M400		

EVENT TYPE EVENT MESSAGE ZONE NUMBER

↓

2A OPTIONAL LED DISPLAY

LOCATION

↓

3 LOCAL SILENCE

↓

4 ALARM REVIEW

LED LEGEND

- = OFF
- ★ = ON STEADY
- ★/★ = FLASH

1: AC POWER, ALARM, SUPERVISORY, TROUBLE, MONITOR

6: DISABLE, GND FAULT, CPU FAIL, TEST

5: RESET, ALARM SILENCE, LOCAL SILENCE, DRILL

3: REVIEW screen

2: REVIEW screen

2A: REVIEW screen

4: Keypad

6: SYSTEM RESET diagram

5: ALARM SILENCE diagram

ALARM

(written instructions on opposite page)